

OLIVE ONE STOP SHOP
421 N OLIVE ST
SOUTH BEND

APR 26, 2025 2:48 PM

LEAK TEST REPORT

T 1:UNLEADED
PROBE SERIAL NUM 426738

TEST STARTING TIME:
APR 21, 2025 1:30 AM

HEIGHT = 14.7 INCHES
WATER = 0.0 INCHES
TEMP = 51.8 F

TEST LENGTH = 2.0 HRS
STRT VOLUME = 1553.2 GAL
PERCENT VOLUME = 10.4

LEAK TEST RESULTS
0.20 GAL/HR TEST INVL

0.20 GAL/HR FLAGS:
LOW LEVEL TEST ERROR
PERCENT VOLUME TOO LOW

* * * * * END * * * * *

OLIVE ONE STOP SHOP
421 N OLIVE ST
SOUTH BEND

APR 26, 2025 2:48 PM

LEAK TEST REPORT

T 2:PREMIUM
PROBE SERIAL NUM 426739

TEST STARTING TIME:
APR 21, 2025 1:30 AM

HEIGHT = 14.2 INCHES
WATER = 0.0 INCHES
TEMP = 54.3 F

TEST LENGTH = 2.0 HRS
STRT VOLUME = 465.4 GAL
PERCENT VOLUME = 9.1

LEAK TEST RESULTS
0.20 GAL/HR TEST INVL

0.20 GAL/HR FLAGS:
LOW LEVEL TEST ERROR
PERCENT VOLUME TOO LOW

* * * * * END * * * * *