

OLIVE ONE STOP SHOP
421 N OLIVE ST
SOUTH BEND

FEB 23, 2025 5:59 PM

LEAK TEST REPORT

T 1:UNLEADED
PROBE SERIAL NUM 426738

TEST STARTING TIME:
FEB 17, 2025 1:30 AM

HEIGHT = 57.2 INCHES
WATER = 0.0 INCHES
TEMP = 37.6 F

TEST LENGTH = 4.0 HRS
STRT VOLUME = 10115.3 GAL
PERCENT VOLUME = 68.0

LEAK TEST RESULTS
RATE = -11.36 GAL/HR
THRS = -0.13 GAL/HR
0.20 GAL/HR TEST FAIL

* * * * * END * * * * *

OLIVE ONE STOP SHOP
421 N OLIVE ST
SOUTH BEND

FEB 23, 2025 5:59 PM

LEAK TEST REPORT

T 2:PREMIUM
PROBE SERIAL NUM 426739

TEST STARTING TIME:
FEB 17, 2025 1:30 AM

HEIGHT = 17.9 INCHES
WATER = 0.0 INCHES
TEMP = 45.8 F

TEST LENGTH = 4.0 HRS
STRT VOLUME = 666.6 GAL
PERCENT VOLUME = 13.1

LEAK TEST RESULTS
0.20 GAL/HR TEST INVL

0.20 GAL/HR FLAGS:
LOW LEVEL TEST ERROR
PERCENT VOLUME TOO LOW

* * * * * END * * * * *