



5296 Breakers Way, Carmel, IN 46033

Date 10/22/25

PRODUCT LINE TEST

Test Location Information

Name	FID 14296
Address	421 N Olive St
City	South Bend, IN, 46628
Phone	
Contact	

Technician Information

Name	Josh Rider
Cert #	UC202406986

Applied Pressure

50 psi

#1 Product Type : Regular

TIME	DATA	+/-	GPL	RES	GPH
12:15p	86	0	0.0037	0	0
12:30p	76	-10	0.0037	.037	.148
12:45p	70	-6	0.0037	.0222	.0888
			0.0037		
			0.0037		
			0.0037		
			0.0037		
Final Result : Fail					

#2 Product Type : Premium

TIME	DATA	+/-	GPL	RES	GPH
1:05pm	77	0	0.0037	0	0
1:20pm	73	-4	0.0037	.0148	.0592
1:35pm	71	-2	0.0037	.0074	.0296
1:50pm	69	-2	0.0037	.0074	.0296
			0.0037		
			0.0037		
			0.0037		
Final Result : Pass					

#3 Product Type :

TIME	DATA	+/-	GPL	RES	GPH
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
Final Result : .					

#4 Product Type :

TIME	DATA	+/-	GPL	RES	GPH
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
Final Result : .					



5296 Breakers Way, Carmel, IN 46033

Date 10/22/25

PRODUCT LINE TEST

Test Location Information

Name	FID 14296
Address	421 N Olive St
City	South Bend, IN, 46628
Phone	
Contact	

Technician Information

Name	Josh Rider
Cert #	UC202406986

Applied Pressure

50 psi

FINAL REPORT

SR. No.	Product Type	Result
1	Regular	Fail
2	Premium	Pass
3		
4		
5		
6		

Even with silver bullet plug in, product level continued to fall. ATG also has leak alarm on for failed leak test.

Comment :

Tester's Name : Josh Rider

Tester's Signature : 