



5296 Breakers Way, Carmel, IN 46033

www.tanksdata.com  
 tanksdata@gmail.com  
 (317)-300-6065

Date 10/22/25

## LEAK DETECTOR TEST(DATA SHEET)

### Test Location Information

|         |                       |
|---------|-----------------------|
| Name    | FID 14296             |
| Address | 421 N Olive St        |
| City    | South Bend, IN, 46628 |
| Phone   |                       |
| Contact |                       |

### Technician Information

|        |             |
|--------|-------------|
| Name   | Josh Rider  |
| Cert # | UC202406986 |

### TYPE OF LEAK DETECTOR

| PRODUCT TYPE | MAKE          | MODEL | SERIAL# |
|--------------|---------------|-------|---------|
| Reg          | Fe Petro MLLD |       |         |
| Prem         | Fe Petro MLLD |       |         |
|              |               |       |         |
|              |               |       |         |
|              |               |       |         |
|              |               |       |         |
|              |               |       |         |
|              |               |       |         |
|              |               |       |         |

| Pump # | PRODUCT TYPE | Pump Pressure | Functional Element Holding PSI | Resiliency | Test Leak Rate ML/MIN | Opening Time | Pass/Fail |
|--------|--------------|---------------|--------------------------------|------------|-----------------------|--------------|-----------|
| 1      | Regular      | 33            | 31                             | 270 ml     | 189ml                 | 2 sec        | Pass      |
| 2      | Premium      | 34            | 32                             | 220 ml     | 189ml                 | 3 sec        | Pass      |
| 3      |              |               |                                |            | 189ml                 |              | .         |
| 4      |              |               |                                |            | 189ml                 |              | .         |
| 5      |              |               |                                |            | 189ml                 |              | .         |
| 6      |              |               |                                |            | 189ml                 |              | .         |
| 7      |              |               |                                |            | 189ml                 |              | .         |
| 8      |              |               |                                |            | 189ml                 |              | .         |

Comment:

Technician Signature :