

OLIVE ONE STOP SHOP
421 N OLIVE ST
SOUTH BEND

SEP 22, 2025 4:31 PM

LEAK TEST REPORT

T 1:UNLOADED
PROBE SERIAL NUM 426739

TEST STARTING TIME:
SEP 22, 2025 1:30 AM

HEIGHT = 20.1 INCHES
WATER = 0.0 INCHES
TEMP = 69.6 F

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2413.7 GAL
PERCENT VOLUME = 16.2

LEAK TEST RESULTS
0.20 GAL/HR TEST INVL

0.20 GAL/HR FLAGS:
LOW LEVEL TEST ERROR
PERCENT VOLUME TOO LOW

* * * * * END * * * * *

OLIVE ONE STOP SHOP
421 N OLIVE ST
SOUTH BEND

SEP 25, 2025 4:31 PM

LEAK TEST REPORT

T 2:PREMIUM
PROBE SERIAL NUM 426739

TEST STARTING TIME:
SEP 22, 2025 1:30 AM

HEIGHT = 27.6 INCHES
WATER = 0.0 INCHES
TEMP = 70.0 F

TEST LENGTH = 2.0 HRS
STRT VOLUME = 1252.4 GAL
PERCENT VOLUME = 24.6

LEAK TEST RESULTS
0.20 GAL/HR TEST INVL

0.20 GAL/HR FLAGS:
LOW LEVEL TEST ERROR
PERCENT VOLUME TOO LOW