

157530 7ELEVEN 27056
601 N MAIN ST
MISHAWAKA, IN 46545
A0267750605001

SEP 2, 2024 3:15 PM

CSLD TEST RESULTS

SEP 2, 2024 3:15 PM

T 1:RUL
PROBE SERIAL NUM 142259

0.2 GAL/HR TEST
PER: SEP 2, 2024 PASS

T 2:PUL
PROBE SERIAL NUM 476729

0.2 GAL/HR TEST
PER: SEP 2, 2024 PASS

T 3:DSL
PROBE SERIAL NUM 476730

0.2 GAL/HR TEST
PER:NO RESULTS AVAILABLE

* * * * * END * * * * *

PMC STATUS

PMC VERSION: 01.04

NO RECORDS

157530 7ELEVEN 27056
601 N MAIN ST
MISHAWAKA, IN 46545
A0267750505001

SEP 2, 2024 3:15 PM

LEAK TEST REPORT

T 1:RUL
PROBE SERIAL NUM 142259

NO TEST DATA AVAILABLE

* * * * * END * * * * *

157530 7ELEVEN 27056
601 N MAIN ST
MISHAWAKA, IN 46545
A0267750505001

SEP 2, 2024 3:15 PM

LEAK TEST REPORT

T 2:PUL
PROBE SERIAL NUM 476729

NO TEST DATA AVAILABLE

* * * * * END * * * * *

157530 7ELEVEN 27056
601 N MAIN ST
MISHAWAKA, IN 46545
A0267750505001

SEP 2, 2024 3:15 PM

LEAK TEST REPORT

T 3:DSL
PROBE SERIAL NUM 476730

NO TEST DATA AVAILABLE

* * * * * END * * * * *