

157530 SEVEN 27056
601 N MAIN ST
MISHAWAKA, IN 46545
A0267750605001

JAN 13, 2025 1:00 PM

CSLD TEST RESULTS

- - - - -
JAN 13, 2025 1:00 PM

T 1:RUL

PROBE SERIAL NUM 142259

0.2 GAL/HR TEST

PER: JAN 13, 2025 PASS

T 2:PUL

PROBE SERIAL NUM 476729

0.2 GAL/HR TEST

PER: JAN 13, 2025 PASS

T 3:DSL

PROBE SERIAL NUM 476730

0.2 GAL/HR TEST

PER: JAN 13, 2025 PASS

* * * * * END * * * * *

PMC STATUS

PMC VERSION: 01.04

NO RECORDS

157530 7ELEVEN 27056
601 N MAIN ST
MISHAWAKA, IN 46545
A0267750605001

JAN 13, 2025 1:00 PM

LEAK TEST REPORT

T 1:RUL

PROBE SERIAL NUM 142259

NO TEST DATA AVAILABLE

* * * * * END * * * * *

157530 7ELEVEN 27056
601 N MAIN ST
MISHAWAKA, IN 46545
A0267750605001

JAN 13, 2025 1:00 PM

LEAK TEST REPORT

T 2:PUL

PROBE SERIAL NUM 476729

NO TEST DATA AVAILABLE

* * * * * END * * * * *

157530 7ELEVEN 27056
601 N MAIN ST
MISHAWAKA, IN 46545
A0267750605001

JAN 13, 2025 1:00 PM

LEAK TEST REPORT

T 3:DSL

PROBE SERIAL NUM 476730

NO TEST DATA AVAILABLE

* * * * * END * * * * *