

30 DAYS WALK THROUGH INSPECTION

000
Tanks Data

UST Facility I.D. (FID) #	12240	Contact Number	
Facility Name	MOBILE	Contact email	
Address	601 N Main St, Mishawaka, IN 46545	Date of Inspection	01/13/25
Operator on Duty Name		Name of the Person Conducting Inspection	AKSHIT

Operator Training current	☒ Yes	☐ No	Operator Notified	☐ Yes	☐ No
Is Registration current with correct owner, operator etc.	☐ Yes	☐ No	Operator Notified	☐ Yes	☐ No
Release Detection Method	☒ ATG ☐ Does it have paper? ☐ Is it in Alarm mode? ☐ Interstitial Monitoring Sensor Status Normal ☐ Necessary Monthly Printout Taken	☐ TIM ☐ BIR ☐ IC ☐ Other	Operator Notified	☐ Yes	☐ No
Are Spill Buckets Clean and free from water, debris, product etc?	☒ Yes	☐ No	Operator Notified	☐ Yes	☐ No
Are the Spill Bucket in good condition and free of damage/cracks	☒ Yes	☐ No	Operator Notified	☐ Yes	☐ No
Is Fill pipe cap tight and fill pipe free from any obstruction?	☒ Yes	☐ No	Operator Notified	☐ Yes	☐ No
Are Sumps Clean and free from water, debris, product etc?	☐ Yes	☒ No	Operator Notified	☒ Yes	☐ No
Are UDCs clean and free from water, debris, product etc?	☒ Yes	☐ No	Operator Notified	☐ Yes	☐ No

NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.

Operator on Duty Name _____ Signature _____ Date _____

317-645-0215 tanksdata@gmail.com www.tanksdata.com