



30 DAYS WALK THROUGH INSPECTION

UST Facility I.D. (FID) # 12290

Contact Number

Facility Name Molis

Contact email

Address 601 N Main St

Date of Inspection 07-10-2025

Operator on Duty Name

Name of the Person Conducting Inspection *[Signature]*

Operator Training		
Operator Training current	☐ Yes	☐ No
Registration/Notification Form		
Is Registration current with correct owner, operator etc.	☐ Yes	☐ No
Release Detection		
Release Detection Method	☒ ATG	☐ CIM
Make and Model	VNTCS-350	
Does it have paper?	☒ Yes	☐ No
Is it in Alarm mode?	☒ Yes	☐ No
Interstitial Monitoring Sensor Status Normal	☒ Yes	☐ No
Necessary Monthly Printout Taken	☒ Yes	☐ No
Spill Buckets		
Are Spill Buckets Clean and free from water, debris, product etc?	☐ Yes	☒ No
Are the Spill Bucket in good condition and free of damage/cracks	☒ Yes	☐ No
Fill Ports		
Is Fill pipe cap tight and fill pipe free from any obstruction?	☐ Yes	☐ No
Piping/STP Sumps		
Are Sumps Clean and free from water, debris, product etc?	☐ Yes	☒ No
Under Dispenser Containments (UDC)		
Are UDCs clean and free from water, debris, product etc?	☐ Yes	☒ No

NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.

Operator on Duty Name

317-645-0215

Signature

tanksdata@gmail.com

Date 07-10-2025

www.tanksdata.com

20220516