

Tanks Data

30 DAYS WALK THROUGH INSPECTION

UST Facility I.D. (FID) #	12240	Contact Number	
Facility Name	Mobile	Contact email	
Address	601 N Main St	Date of Inspection	03/19/25
Operator on Duty Name	Priscilla Ke	Name of the Person Conducting Inspection	Ansley T

Registration/Notification Form		Operator Training	
Is Registration current with correct owner, operator etc.	☒ Yes ☐ No	Operator Training current	☐ Yes ☐ No
Release Detection Method	☒ ATG ☐ TIM ☐ SIR ☐ IC ☐ Other	Release Detection	☐ Yes ☐ No
Make and Model	V2 TLLS - 350	Operator Notified	☐ Yes ☐ No
Does it have paper?	☒ Yes	Operator Notified	☐ Yes ☐ No
Is it in Alarm mode?	☒ Yes	Operator Notified	☒ Yes ☐ No
Interstitial Monitoring Sensor Status Normal	☒ Yes	Operator Notified	☐ Yes ☐ No
Necessary Monthly Printout Taken	☐ Yes	Operator Notified	☐ Yes ☐ No

Spill Buckets		Fill Ports	
Are Spill Buckets Clean and free from water, debris, product etc?	☒ Yes ☐ No	Operator Notified	☐ Yes ☐ No
Are the Spill Bucket in good condition and free of damage/cracks	☒ Yes ☐ No	Operator Notified	☐ Yes ☐ No

Piping/STP Sumps		Under Dispenser Containments (UDC)	
Is Fill pipe cap tight and fill pipe free from any obstruction?	☒ Yes ☐ No	Operator Notified	☐ Yes ☐ No
Are Sumps Clean and free from water, debris, product etc?	☒ Yes ☐ No	Operator Notified	☒ Yes ☐ No
Are UDCs clean and free from water, debris, product etc?	☒ Yes ☐ No	Operator Notified	☐ Yes ☐ No

NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.

Operator on Duty Name _____ Signature _____ Date _____

317-645-0215 tanksdata@gmail.com www.tanksdata.com 20220516