

157530 7ELEVEN 27056
601 N MAIN ST
MISHAWAKA, IN 46545
A0267750605001

MAR 19, 2025 3:47 PM

CSLD TEST RESULTS

- - - - -
MAR 19, 2025 3:47 PM

T 1:RUL
PROBE SERIAL NUM 142259

0.2 GAL/HR TEST
PER: MAR 19, 2025 PASS

T 2:PUL
PROBE SERIAL NUM 476729

0.2 GAL/HR TEST
PER: MAR 19, 2025 PASS

* * * * * END * * * * *

LEAK TEST STATUS:
TEST NOT IN PROGRESS