



5296 Breakers Way, Carmel, IN 46033

www.tanksdata.com
 tanksdata@gmail.com
 (317)-300-6065

Date

1/23/25

LEAK DETECTOR TEST(DATA SHEET)

Test Location Information

Name	FID 12240
Address	601 N Main St
City	Mishawaka, IN, 46545
Phone	
Contact	

Technician Information

Name	Josh Rider
Cert #	UC202406986

TYPE OF LEAK DETECTOR

PRODUCT TYPE	MAKE	MODEL	SERIAL#
Reg	Fe Petro MLLD		
Prem	Red Jacket MLLD		
Dies			

Pump #	PRODUCT TYPE	Pump Pressure	Functional Element Holding PSI	Resiliency	Test Leak Rate ML/MIN	Opening Time	Pass/Fail
1	Regular	33	32	80 ml	189ml	2 sec	Pass
2	Premium	30	28	110 ml	189ml	2 sec	Pass
3	Diesel				189ml		.
4					189ml		.
5					189ml		.
6					189ml		.
7					189ml		.
8					189ml		.

Comment:

Diesel pump is currently not working and I am unable to do the leak test. We will return to test diesel when it is working properly.

Technician Signature :