



5296 Breakers Way, Carmel, IN 46033

Date

1/23/25

PRODUCT LINE TEST

Test Location Information

Name	FID 12240
Address	601 N Main St
City	Mishawaka, IN, 46545
Phone	
Contact	

Technician Information

Name	Josh Rider
Cert #	UC202406986

Applied Pressure

50 psi

#1 Product Type : Regular

TIME	DATA	+/-	GPL	RES	GPH
12:20p	90	0	0.0037	0	0
12:35p	87	-3	0.0037	.0111	.0444
12:50p	85	-2	0.0037	.0074	.0296
1:05pm	84	-1	0.0037	.0037	.0148
			0.0037		
			0.0037		
			0.0037		
Final Result : Pass					

#2 Product Type : Premium

TIME	DATA	+/-	GPL	RES	GPH
1:15pm	88	0	0.0037	0	0
1:30pm	88	0	0.0037	0	0
1:45pm	88	0	0.0037	0	0
			0.0037		
			0.0037		
			0.0037		
			0.0037		
Final Result : Pass					

#3 Product Type : Diesel

TIME	DATA	+/-	GPL	RES	GPH
		0	0.0037	0	0
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
Final Result : .					

#4 Product Type :

TIME	DATA	+/-	GPL	RES	GPH
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
Final Result : .					



5296 Breakers Way, Carmel, IN 46033

Date 1/23/25

PRODUCT LINE TEST

Test Location Information

Name	FID 12240
Address	601 N Main St
City	Mishawaka, IN, 46545
Phone	
Contact	

Technician Information

Name	Josh Rider
Cert #	UC202406986

Applied Pressure

50 psi

FINAL REPORT

SR. No.	Product Type	Result
1	Regular	Pass
2	Premium	Pass
3	Diesel	.
4		.
5		.
6		.

Diesel pump is currently not working and I am unable to do the product test. We will return to test diesel when it is working properly.
Premium line has no ball valve. Silver bullet used to isolate line.

Comment:

Tester's Name : Josh Rider

Tester's Signature : 