

157530 7ELEVEN 27056
601 N MAIN ST
MISHAWAKA, IN 46545
A0267750605001

AUG 13, 2025 3:49 PM

CSLD TEST RESULTS

AUG 13, 2025 3:49 PM

T 1:RUL
PROBE SERIAL NUM 142259

0.2 GAL/HR TEST
PER: AUG 13, 2025 PASS

T 2:PUL
PROBE SERIAL NUM 476729

0.2 GAL/HR TEST
PER:NO RESULTS AVAILABLE

* * * * * END * * * * *

157530 7ELEVEN 27056
601 N MAIN ST
MISHAWAKA, IN 46545
A0267750605001

AUG 13, 2025 3:49 PM

LEAK TEST REPORT

T 1:RUL
PROBE SERIAL NUM 142259

NO TEST DATA AVAILABLE

* * * * * END * * * * *

157530 7ELEVEN 27056
601 N MAIN ST
MISHAWAKA, IN 46545
A0267750605001

AUG 13, 2025 3:49 PM

LEAK TEST REPORT

T 2:PUL
PROBE SERIAL NUM 476729

NO TEST DATA AVAILABLE

* * * * * END * * * * *