

429 N MAIN ST
ELKHART, IN 46516

NOV 28, 2024 17:08

CSLD TEST RESULTS

NOV 28, 2024 17:08

T 1:RUL
PROBE SERIAL NUM 444915

0.2 GAL/HR TEST
PER: NOV 28, 2024 PASS

T 2:PREMIUM
PROBE SERIAL NUM 710749

0.2 GAL/HR TEST
PER: NOV 28, 2024 PASS

* * * * * END * * * * *

429 N MAIN ST
ELKHART, IN 46516

NOV 28, 2024 17:08

LIQUID STATUS

NOV 28, 2024 17:08

L 1:RUL INTERSTITIAL
SENSOR NORMAL

L 2:RUL SUMP
SENSOR NORMAL

L 3:PREM SUMP
SENSOR NORMAL

* * * * * END * * * * *

429 N MAIN ST
ELKHART, IN 46516

NOV 28, 2024 17:08

LEAK TEST REPORT

T 1:RUL
PROBE SERIAL NUM 444915

NO TEST DATA AVAILABLE

* * * * * END * * * * *

429 N MAIN ST
ELKHART, IN 46516

NOV 28, 2024 17:09

LEAK TEST REPORT

T 2:PREMIUM
PROBE SERIAL NUM 710749

NO TEST DATA AVAILABLE

* * * * * END * * * * *