

Elkhart, IN 46516

5296 Breakers Way, Carmel, IN 46033

Facility Name:

City, State, Zip Code:

Address:

	www.tanksdata.com
\boxtimes	tanksdata@gmail.com
3	(317)-300-6065

Date

10/3/24

Expo 24 Hour Mobile 429 N Main St		Owner:
		Address:
	ı	

City, State, Zip Code:

Facility I.D. #:

9066

Phone #:

This procedure is to determine whether the automatic tank guage (ATG) is operating properly. See PEI/RP1200 Section 8.2 for the inspection procedure. This procedure is applicable to tank level monitor stems that touch the bottom of the tank when in place.

Tank Number

1
2

AUTOMATIC TANK GAUGE FUNCTIONALITY TEST

procedure. This procedure is applicable to tank le	vel monitor sten	ns ti		ttor		n in place.	
Tank Number	1		2				
Product Stored	Regular		Premium				
ATG Brand and Model	TLS 350 R		TLS 350 R				
1. Tank Volume, gallons	10,000		6,000				
2. Tank Diameter, inches	90		96				
3. After removing the ATG from the tank, it has been inspected and any damaged or missing parts replaced?	Yes	•	Yes	•			
4. Float moves freely on the stem without binding?	Yes	•	Yes	~			
5. Fuel float level agrees with the value programmed into the console?	Yes	•	Yes	~].
6. Water float level agrees with the value programmed into the console?	Yes	•	Yes	•]. [
7. Inch level from bottom of stem when 90% alarm is triggered.	76		80				
8. Inch level at which the overfill alarm activates corresponds with value programmed in the gauge?	Yes	•	Yes	•			
9. Inch level from the bottom when the water float first triggers an alarm.	2		2				
10. Inch level at which the water float alarm activates corresponds with value programmed in the gauge?	Yes	•	Yes	•			
If any answers in Lines 3, 4, 5, or 6 are "No," the sys	stem has failed t	he t	est.		•		
Test Results	Pass	•	Pass	•	<u></u>	<u>.</u>	1

	Test Results	Pass	•	Pass	▼.	▼.	<u> </u>	•
Comment:								

Josh Rider

Tester's Name :

Tester's Signature :

Josh R