



5296 Breakers Way, Carmel, IN 46033

Date 10/3/24

LIQUID SENSOR FUNCTIONALITY TESTING

Facility Name:	Expo 24 Hour Mobile	Owner:	
Address:	429 N Main St	Address:	
City, State, Zip Code:	Elkhart, IN 46516	City, State, Zip Code:	
Facility I.D. #:	9066	Phone #:	

This procedure is to determine whether liquid sensors located in the interstitial space of UST systems are able to detect the presence of water and fuel. See PEI/RP1200 Section 8.3 for the test procedure.

Sensor Location	IM 1	STP 1	STP 2				
Product Stored	Regular	Regular	Premium				
Type of Sensor	Non-Discriminating	Non-Discriminating	Non-Discriminating				
Test Liquid	Water	Water	Water				
Is the ATG console clear of any active or recurring warnings or alarms regarding the leak sensor? If the sensor is in alarm and functioning, indicate why.	Yes	Yes	Yes				
Is the sensor alarm circuit operational?	Yes	Yes	Yes				
Has sensor been inspected and in good operating condition?	Yes	Yes	Yes				
When placed in the test liquid, does the sensor trigger an alarm?	Yes	Yes	Yes				
When an alarm is triggered, is the sensor properly identified on the ATG console?	Yes	Yes	Yes				
Any "No" answers indicates the sensor fails the test.							
Test Results	Pass	Pass	Pass				

Comment

Tester's Name : Josh Rider

Tester's Signature :