

429 N MAIN ST  
ELKHART, IN 46516

OCT 28, 2024 18:11

TANK LEAK TEST HISTORY

T 1:RUL

LAST GROSS TEST PASSED:

NO TEST PASSED

LAST ANNUAL TEST PASSED:

NO TEST PASSED

FULLEST ANNUAL TEST PASS

NO TEST PASSED

LAST PERIODIC TEST PASS:

OCT 28, 2024 11:46  
TEST LENGTH 30 HOURS  
STARTING VOLUME = 4837  
PERCENT VOLUME = 50.0  
TEST TYPE = CSLD

FULLEST PERIODIC TEST  
PASSED EACH MONTH:

JAN 22, 2024 9:49  
TEST LENGTH 25 HOURS  
STARTING VOLUME = 5292  
PERCENT VOLUME = 54.7  
TEST TYPE = CSLD

FEB 27, 2024 7:15  
TEST LENGTH 24 HOURS  
STARTING VOLUME = 5796  
PERCENT VOLUME = 59.9  
TEST TYPE = CSLD

429 N MAIN ST  
ELKHART, IN 46516

OCT 28, 2024 18:11

TANK LEAK TEST HISTORY

T 2:PREMIUM

LAST GROSS TEST PASSED:

NO TEST PASSED

LAST ANNUAL TEST PASSED:

NO TEST PASSED

FULLEST ANNUAL TEST PASS

NO TEST PASSED

LAST PERIODIC TEST PASS:

OCT 28, 2024 16:16  
TEST LENGTH 29 HOURS  
STARTING VOLUME = 1544  
PERCENT VOLUME = 24.2  
TEST TYPE = CSLD

FULLEST PERIODIC TEST  
PASSED EACH MONTH:

JAN 1, 2024 2:57  
TEST LENGTH 30 HOURS  
STARTING VOLUME = 1875  
PERCENT VOLUME = 29.4  
TEST TYPE = CSLD

MAR 16, 2024 5:00  
TEST LENGTH 27 HOURS  
STARTING VOLUME = 6281  
PERCENT VOLUME = 64.9  
TEST TYPE = CSLD

FEB 28, 2024 7:16  
TEST LENGTH 26 HOURS  
STARTING VOLUME = 2299  
PERCENT VOLUME = 36.1  
TEST TYPE = CSLD

APR 29, 2024 7:21  
TEST LENGTH 26 HOURS  
STARTING VOLUME = 6014  
PERCENT VOLUME = 62.1  
TEST TYPE = CSLD

429 N MAIN ST  
ELKHART, IN 46516

OCT 28, 2024 18:11

TANK LEAK TEST HISTORY

T 3:

LAST GROSS TEST PASSED:

NO TEST PASSED

LAST ANNUAL TEST PASSED:

NO TEST PASSED

FULLEST ANNUAL TEST PASS

NO TEST PASSED

LAST PERIODIC TEST PASS:

NO TEST PASSED

FULLEST PERIODIC TEST  
PASSED EACH MONTH:

429 N MAIN ST  
ELKHART, IN 46516

OCT 28, 2024 18:11

TANK LEAK TEST HISTORY

T 4:

LAST GROSS TEST PASSED:

NO TEST PASSED

LAST ANNUAL TEST PASSED:

NO TEST PASSED

FULLEST ANNUAL TEST PASS

NO TEST PASSED  
LAST PERIODIC TEST PASS:  
NO TEST PASSED  
FULLEST PERIODIC TEST  
PASSED EACH MONTH:  
MAR 3. 2024 8:31  
TEST LENGTH 34 HOURS  
STARTING VOLUME= 2161  
PERCENT VOLUME = 33.9  
TEST TYPE = CSLD  
MAY 1. 2024 2:33  
TEST LENGTH 25 HOURS  
STARTING VOLUME= 6161  
PERCENT VOLUME = 63.6  
TEST TYPE = CSLD  
APR 30. 2024 3:20  
TEST LENGTH 29 HOURS  
STARTING VOLUME= 1333  
PERCENT VOLUME = 20.9  
TEST TYPE = CSLD  
JUN 23. 2024 7:38  
TEST LENGTH 25 HOURS  
STARTING VOLUME= 6545  
PERCENT VOLUME = 67.6  
TEST TYPE = CSLD  
MAY 28. 2024 6:21  
TEST LENGTH 25 HOURS  
STARTING VOLUME= 1704  
PERCENT VOLUME = 26.7  
TEST TYPE = CSLD  
JUL 26. 2024 1:28  
TEST LENGTH 25 HOURS  
STARTING VOLUME= 6471  
PERCENT VOLUME = 66.8  
TEST TYPE = CSLD  
JUN 1. 2024 3:43  
TEST LENGTH 27 HOURS  
STARTING VOLUME= 1694  
PERCENT VOLUME = 26.6  
TEST TYPE = CSLD  
AUG 3. 2024 6:12  
TEST LENGTH 24 HOURS  
STARTING VOLUME= 6183  
PERCENT VOLUME = 63.8  
TEST TYPE = CSLD  
JUL 31. 2024 23:53  
TEST LENGTH 31 HOURS  
STARTING VOLUME= 2039  
PERCENT VOLUME = 32.0  
TEST TYPE = CSLD  
SEP 25. 2024 2:25  
TEST LENGTH 24 HOURS  
STARTING VOLUME= 5645  
PERCENT VOLUME = 58.3  
TEST TYPE = CSLD  
AUG 30. 2024 2:18  
TEST LENGTH 29 HOURS  
STARTING VOLUME= 2458  
PERCENT VOLUME = 38.6  
TEST TYPE = CSLD  
OCT 10. 2024 4:04  
TEST LENGTH 29 HOURS  
STARTING VOLUME= 5490  
PERCENT VOLUME = 55.7  
TEST TYPE = CSLD  
SEP 1. 2024 4:28  
TEST LENGTH 30 HOURS  
STARTING VOLUME= 2439  
PERCENT VOLUME = 38.3  
TEST TYPE = CSLD  
NOV 19. 2023 8:50  
TEST LENGTH 26 HOURS  
STARTING VOLUME= 4961  
PERCENT VOLUME = 51.2  
TEST TYPE = CSLD  
OCT 28. 2024 16:16  
TEST LENGTH 29 HOURS  
STARTING VOLUME= 1544  
PERCENT VOLUME = 24.2  
TEST TYPE = CSLD  
DEC 20. 2023 5:34  
TEST LENGTH 28 HOURS  
STARTING VOLUME= 4822  
PERCENT VOLUME = 49.8  
TEST TYPE = CSLD  
\* \* \* \* \* END \* \* \* \* \*  
NOV 30. 2023 6:31  
TEST LENGTH 23 HOURS  
STARTING VOLUME= 1771  
PERCENT VOLUME = 27.8  
TEST TYPE = CSLD  
DEC 17. 2023 8:52  
TEST LENGTH 31 HOURS  
STARTING VOLUME= 1982  
PERCENT VOLUME = 31.1  
TEST TYPE = CSLD  
\* \* \* \* \* END \* \* \* \* \*