

429 N MAIN ST
ELKHART, IN 46516

DEC 23, 2024 17:00

CSLD TEST RESULTS

- - - - -
DEC 23, 2024 17:00

T 1:RUL
PROBE SERIAL NUM 444915

0.2 GAL/HR TEST
PER: DEC 23, 2024 PASS

T 2:PREMIUM
PROBE SERIAL NUM 710749

0.2 GAL/HR TEST
PER: DEC 23, 2024 PASS

* * * * * END * * * * *

429 N MAIN ST
ELKHART, IN 46516

DEC 23, 2024 17:00

LIQUID STATUS

- - - - -
DEC 23, 2024 17:00

L 1:RUL INTERSTITIAL
SENSOR NORMAL

L 2:RUL SUMP
SENSOR NORMAL

L 3:PREM SUMP
SENSOR NORMAL

* * * * * END * * * * *

429 N MAIN ST
ELKHART, IN 46516

DEC 23, 2024 17:00

LEAK TEST REPORT

T 1:RUL
PROBE SERIAL NUM 444915

NO TEST DATA AVAILABLE

* * * * * END * * * * *

429 N MAIN ST
ELKHART, IN 46516

DEC 23, 2024 17:00

LEAK TEST REPORT

T 2:PREMIUM
PROBE SERIAL NUM 710749

NO TEST DATA AVAILABLE

* * * * * END * * * * *