

429 N MAIN ST
ELKHART, IN 46516

SEP 15, 2024 15:00

LEAK TEST REPORT

T 1:RUL
PROBE SERIAL NUM 710749

NO TEST DATA AVAILABLE

* * * * * END * * * * *

429 N MAIN ST
ELKHART, IN 46516

SEP 15, 2024 15:30

LEAK TEST REPORT

T 2:PREMIUM
PROBE SERIAL NUM 444915

NO TEST DATA AVAILABLE

* * * * * END * * * * *

ELKHART, IN 46516

SEP 15, 2024 15:30

CSLD TEST RESULTS

SEP 15, 2024 15:30

T 1:RUL

PROBE SERIAL NUM 710749

0.2 GAL/HR TEST

PER: SEP 15, 2024 PASS

T 2:PREMIUM

PROBE SERIAL NUM 444915

0.2 GAL/HR TEST

PER: SEP 15, 2024 PASS

***** END *****

429 N MAIN ST
ELKHART, IN 46516

SEP 15, 2024 15:30

LIQUID STATUS

SEP 15, 2024 15:30

L 1:RUL INTERSTITIAL
SENSOR NORMAL

L 2:RUL SUMP
SENSOR NORMAL

L 3:PREM SUMP
SENSOR NORMAL