

429 N MAIN ST
ELKHART, IN 46516

SEP 29, 2025 16:28

CSLD TEST RESULTS

SEP 29, 2025 16:28

T 1:RUL
PROBE SERIAL NUM 444915

0.2 GAL/HR TEST
PER: SEP 29, 2025 PASS

T 2:PREMIUM
PROBE SERIAL NUM 710749

0.2 GAL/HR TEST
PER: SEP 29, 2025 PASS

* * * * * END * * * * *

429 N MAIN ST
ELKHART, IN 46516

SEP 29, 2025 16:28

LIQUID STATUS

SEP 29, 2025 16:28

L 1:RUL INTERSTITIAL
SENSOR NORMAL

L 2:RUL SUMP
SENSOR NORMAL

L 3:PREM SUMP
SENSOR NORMAL

* * * * * END * * * * *