

429 N MAIN ST
ELKHART, IN 46516

JUN 26, 2025 17:21

CSLD TEST RESULTS - - - -

JUN 26, 2025 17:21

T 1:RUL
PROBE SERIAL NUM 444915

0.2 GAL/HR TEST
PER: JUN 26, 2025 PASS

T 2:PREMIUM
PROBE SERIAL NUM 710749

0.2 GAL/HR TEST
PER: JUN 26, 2025 PASS

* * * * * END * * * * *

429 N MAIN ST
ELKHART, IN 46516

JUN 26, 2025 17:21

LIQUID STATUS - - - - -

JUN 26, 2025 17:21

L 1:RUL INTERSTITIAL
SENSOR NORMAL

L 2:RUL SUMP
SENSOR NORMAL

L 3:PREM SUMP
SENSOR NORMAL

* * * * * END * * * * *

429 N MAIN ST
ELKHART, IN 46516

JUN 26, 2025 17:21

LEAK TEST REPORT

T 1:RUL
PROBE SERIAL NUM 444915

NO TEST DATA AVAILABLE

* * * * * END * * * * *

429 N MAIN ST
ELKHART, IN 46516

JUN 26, 2025 17:21

LEAK TEST REPORT

T 2:PREMIUM
PROBE SERIAL NUM 710749

NO TEST DATA AVAILABLE

* * * * * END * * * * *