

429 N MAIN ST
ELKHART, IN 46516

MAR 23, 2025 17:41

CSLD TEST RESULTS

MAR 23, 2025 17:41

T 1:RUL
PROBE SERIAL NUM 444915

0.2 GAL/HR TEST
PER: MAR 23, 2025 PASS

T 2:PREMIUM
PROBE SERIAL NUM 710749

0.2 GAL/HR TEST
PER: MAR 23, 2025 PASS

* * * * * END * * * * *

429 N MAIN ST
ELKHART, IN 46516

MAR 23, 2025 17:41

LIQUID STATUS

MAR 23, 2025 17:41

L 1:RUL INTERSTITIAL
SENSOR NORMAL

L 2:RUL SUMP
SENSOR NORMAL

L 3:PREM SUMP
SENSOR NORMAL

* * * * * END * * * * *

LEAK TEST STATUS:
TEST NOT IN PROGRESS