



5296 Breakers Way, Carmel, IN 46033

 www.tanksdata.com
 tanksdata@gmail.com
 (317)-300-6065

Date

10/20/25

LEAK DETECTOR TEST(DATA SHEET)

Test Location Information

Name	FID 9066
Address	429 N Main St
City	Elkhart, IN, 46516
Phone	
Contact	

Technician Information

Name	Josh Rider
Cert #	UC202406986

TYPE OF LEAK DETECTOR

PRODUCT TYPE	MAKE	MODEL	SERIAL#
Reg	Fe Petro MLLD		
Prem	Fe Petro MLLD		

Pump #	PRODUCT TYPE	Pump Pressure	Functional Element Holding PSI	Resiliency	Test Leak Rate ML/MIN	Opening Time	Pass/Fail
1	Regular	27	25	130 ml	189ml	2 sec	Pass 
2	Premium	26	25	1000+ ml	189ml	6 sec	Pass 
3					189ml		. 
4					189ml		. 
5					189ml		. 
6					189ml		. 
7					189ml		. 
8					189ml		. 

Comment:

Technician Signature :

