

429 N MAIN ST
ELKHART, IN 46516

AUG 24, 2025 17:59

CSLD TEST RESULTS

AUG 24, 2025 17:59

T 1:RUL
PROBE SERIAL NUM 444915

0.2 GAL/HR TEST
PER: AUG 24, 2025 PASS

T 2:PREMIUM
PROBE SERIAL NUM 710749

0.2 GAL/HR TEST
PER: AUG 24, 2025 PASS

* * * * * END * * * * *

429 N MAIN ST
ELKHART, IN 46516

AUG 24, 2025 17:59

LIQUID STATUS

AUG 24, 2025 17:59

L 1:RUL INTERSTITIAL
SENSOR NORMAL

L 2:RUL SUMP
SENSOR NORMAL

L 3:PREM SUMP
SENSOR NORMAL

* * * * * END * * * * *