

429 N MAIN ST
ELKHART, IN 46516

JAN 28, 2025 8:00

CSLD TEST RESULTS

JAN 28, 2025 8:00

T 1:RUL

PROBE SERIAL NUM 444915

0.2 GAL/HR TEST

PER: JAN 28, 2025 PASS

T 2:PREMIUM

PROBE SERIAL NUM 710749

0.2 GAL/HR TEST

PER: JAN 28, 2025 PASS

429 N MAIN ST

ELKHART, IN 46516

JAN 28, 2025 18:17

LIQUID STATUS

JAN 28, 2025 18:17

L 1:RUL INTERSTITIAL

SENSOR NORMAL

L 2:RUL SUMP

SENSOR NORMAL

L 3:PREM SUMP

SENSOR NORMAL

* * * * * END * * * * *

429 N MAIN ST

ELKHART, IN 46516

JAN 28, 2025 18:17

LEAK TEST REPORT

T 1:RUL

PROBE SERIAL NUM 444915

NO TEST DATA AVAILABLE

* * * * * END * * * * *

PMC STATUS

PMC VERSION: 01.04

NO RECORDS

429 N MAIN ST

ELKHART, IN 46516

JAN 28, 2025 18:17

LEAK TEST REPORT

T 2:PREMIUM

PROBE SERIAL NUM 710749

NO TEST DATA AVAILABLE

* * * * * END * * * * *