



30 DAYS WALK THROUGH INSPECTION

UST Facility I.D. (FID) # 9066
Facility Name Mobile
Address 479W Main St 46516
Operator on Duty Name

Contact Number
Contact email
Date of Inspection 08-24-2025
Name of the Person Conducting Inspection Gurpreet

Operator Training current
Is Registration current with correct owner, operator etc.
Release Detection Method
Make and Model VRTLS-3 SOR
Does it have paper?
Is it in Alarm mode?
Interstitial Monitoring Sensor Status Normal
Necessary Monthly Printout Taken
Are Spill Buckets Clean and free from water, debris, product etc?
Are the Spill Bucket in good condition and free of damage/cracks
Is Fill pipe cap tight and fill pipe free from any obstruction?
Are Sumps Clean and free from water, debris, product etc?
Are UDCs clean and free from water, debris, product etc?

Operator Training

☐ Yes ☐ No

Registration/Notification Form

☐ Yes ☐ No

Release Detection

☒ ATG ☐ CIM

☒ Yes ☐ No

☐ Yes ☒ No

☒ Yes ☐ No

☒ Yes ☐ No

Spill Buckets

☒ Yes ☐ No

☒ Yes ☐ No

Fill Ports

☐ Yes ☐ No

Piping/STP Sumps

☐ Yes ☒ No

Under Dispenser Containments (UDC)

☐ Yes ☒ No

Operator Notified ☐ Yes ☐ No

Operator Notified ☐ Yes ☐ No

☐ SIR ☐ IC ☐ Other

Operator Notified ☐ Yes ☐ No

Operator Notified ☐ Yes ☐ No

Operator Notified ☐ Yes ☐ No

Operator Notified ☐ Yes ☐ No

Operator Notified ☒ Yes ☐ No

Operator Notified ☐ Yes ☐ No

Operator Notified ☐ Yes ☐ No

Operator Notified ☒ Yes ☐ No

Operator Notified ☒ Yes ☐ No

NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.

Operator on Duty Name

317-645-0215

Signature

tanksdata@gmail.com

Date

www.tanksdata.com