

429 N MAIN ST
ELKHART, IN 46516

JUL 23, 2025 19:50

CSLD TEST RESULTS

- - - - -

JUL 23, 2025 19:50

T 1:RUL

PROBE SERIAL NUM 444915

0.2 GAL/HR TEST

PER: JUL 23, 2025 PASS

T 2:PREMIUM

PROBE SERIAL NUM 710749

0.2 GAL/HR TEST

PER: JUL 23, 2025 PASS

* * * * * END * * * * *

429 N MAIN ST
ELKHART, IN 46516

JUL 23, 2025 19:50

LIQUID STATUS

- - - - -

JUL 23, 2025 19:50

L 1:RUL INTERSTITIAL
SENSOR NORMAL

L 2:RUL SUMP
SENSOR NORMAL

L 3:PREM SUMP
SENSOR NORMAL

* * * * * END * * * * *