



5296 Breakers Way, Carmel, IN 46033

Date

9/17/24

PRODUCT LINE TEST

Test Location Information

Name	FID 16559
Address	20 N Chestnut St
City	Monrovia
Phone	
Contact	

Technician Information

Name	Josh Rider
Cert #	UC202406986

Applied Pressure

50 psi

#1 Product Type : Regular

TIME	DATA	+/-	GPL	RES	GPH
11:30am	90	0	0.0037	0	0
11:45a	90	0	0.0037	0	0
12:00p	90	0	0.0037	0	0
			0.0037		
			0.0037		
			0.0037		
			0.0037		
Final Result : Pass					

#2 Product Type : Premium

TIME	DATA	+/-	GPL	RES	GPH
12:20p	84	0	0.0037	0	0
12:35p	84	0	0.0037	0	0
12:50p	84	0	0.0037	0	0
			0.0037		
			0.0037		
			0.0037		
			0.0037		
Final Result : Pass					

#3 Product Type : Diesel

TIME	DATA	+/-	GPL	RES	GPH
1:15pm	81	0	0.0037	0	0
1:30pm	81	0	0.0037	0	0
1:45pm	81	0	0.0037	0	0
			0.0037		
			0.0037		
			0.0037		
			0.0037		
Final Result : Pass					

#4 Product Type :

TIME	DATA	+/-	GPL	RES	GPH
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
Final Result : .					



5296 Breakers Way, Carmel, IN 46033

Date 9/17/24

PRODUCT LINE TEST

Test Location Information

Name	FID 16559
Address	20 N Chestnut St
City	Monrovia
Phone	
Contact	

Technician Information

Name	Josh Rider
Cert #	UC202406986

Applied Pressure

50 psi

FINAL REPORT

SR. No.	Product Type	Result
1	Regular	Pass
2	Premium	Pass
3	Diesel	Pass
4		.
5		.
6		.

Comment :

Tester's Name : Josh Rider

Tester's Signature : 