

UST OVERFILL EQUIPMENT INSPECTION AUTOMATIC SHUTOFF DEVICE AND BALL FLOAT VALVE

Facility Name:	Monrovia Food Mart	Owner:	Monrovia Food Mart
Address:	20 N Chestnut St	Address:	20 N Chestnut St
City, State, Zip Code:	Monrovia, IN 46157	City, State, Zip Code:	Monrovia, IN 46157
Facility I.D. #:	16559	Phone #:	16559

This data sheet is for inspecting automatic shutoff devices and ball float valves. See PEI/RP1200 Section 7 for inspection procedures.

Product Grade	Regular 1	Premium	Diesel	Regular 2		
Tank Number	1	2	3	4		
Tank Volume, gallons	4,000	5,000	4,000	1,000		
Tank Diameter, inches	64	72	64	64		
Overfill Prevention Device Brand	OPW	OPW	OPW	OPW		
Type of Overfill Device	BF/ASD	BF/ASD	BF/ASD	BF/ASD		

AUTOMATIC SHUTOFF DEVICE INSPECTION

1. Drop tube removed from tank?	Yes	Yes	Yes	Yes		
2. Drop tube and float mechanisms free of debris?	Yes	Yes	Yes	Yes		
3. Float moves freely without binding and poppet moves into flow path?	Yes	Yes	Yes	Yes		
4. Bypass valve in the drop tube open and free of blockage (if present)?	Yes	Yes	Yes	Yes		
5. Flapper adjusted to shut off flow at 95% capacity?*	No	No	No	No		
6. Is Ball Float Present?						
7. Measured Auto Shut-Off Level						

A "No" to any item in Lines 1-5 indicates a test failure.

BALL FLOAT VALVE INSPECTION

1. Tank top fittings vapor-tight and leak-free?						
2. Ball float cage free of debris?						
3. Ball free of holes and cracks and moves freely in cage?						
4. Vent hole in pipe open and near top of tank?						
5. Ball float pipe proper length to restrict flow at 90% capacity?*						
6. Ball Float removed from the tank?						
7. Ball Float Level						

A "No" to any item in Lines 1-5 indicates a test failure.

Test Results	Pass	Pass	Pass	Pass		
--------------	------	------	------	------	--	--

Comment: Site has a history of ball floats but I did not physically see them. New flapper drop tubes installed and set at 90%, not 95%.

* Use manufacturer's suggested procedure for determining if automatic shutoff device will shut off flow at 95% capacity.

** Use manufacturer's suggested procedure for determining if flow restriction device will restrict flow at 90% capacity.

Tester's Name : Josh Rider

Tester's Signature : 