

30 DAYS WALK THROUGH INSPECTION

Tanks Data

UST Facility I.D. (FID) #	16559	Contact Number	
Facility Name	SUNOCO	Contact email	
Address	20 Chestnut St, Monaca, CA 91351	Date of Inspection	02/19/25
Operator on Duty Name	1246157	Name of the Person Conducting Inspection	AKSHIT

NO REF
PRINT

Operator Training current	☒ Yes	☐ No	Operator Notified	☐ Yes	☐ No
Registration/Notification Form	☐ Yes	☐ No	Operator Notified	☐ Yes	☐ No
Release Detection Method	☒ ATG ☐ CIM ☐ BIR ☐ IC ☐ Other				
Is Registration current with correct owner, operator etc.	☐ Yes	☐ No	Operator Notified	☐ Yes	☐ No
Release Detection	☒ Yes	☐ No	Operator Notified	☐ Yes	☐ No
Make and Model	NANO				
Does it have paper?	☒ Yes	☐ No	Operator Notified	☐ Yes	☐ No
Is it in Alarm mode?	☒ Yes	☐ No	Operator Notified	☐ Yes	☐ No
Interstitial Monitoring Sensor Status Normal	☐ Yes	☐ No	Operator Notified	☐ Yes	☐ No
Necessary Monthly Printout Taken	☐ Yes	☐ No	Operator Notified	☐ Yes	☐ No
Spill Buckets	☒ Yes	☐ No	Operator Notified	☐ Yes	☐ No
Are Spill Buckets Clean and free from water, debris, product etc?	☒ Yes	☐ No	Operator Notified	☐ Yes	☐ No
Are the Spill Bucket in good condition and free of damage/cracks	☒ Yes	☐ No	Operator Notified	☐ Yes	☐ No
Fill Ports	☒ Yes	☐ No	Operator Notified	☐ Yes	☐ No
Is Fill pipe cap tight and fill pipe free from any obstruction?	☒ Yes	☐ No	Operator Notified	☐ Yes	☐ No
Pipeline/STP Sumps	☒ Yes	☐ No	Operator Notified	☐ Yes	☐ No
Are Sumps Clean and free from water, debris, product etc?	☒ Yes	☐ No	Operator Notified	☐ Yes	☐ No
Under Dispenser Containments (UDC)	☒ Yes	☐ No	Operator Notified	☐ Yes	☐ No
Are UDCs clean and free from water, debris, product etc?	☒ Yes	☐ No	Operator Notified	☐ Yes	☐ No

NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.

Operator on Duty Name: tanksdata@gmail.com

Signature: _____ Date: _____

317-645-0215

www.tanksdata.com