



5296 Breakers Way, Carmel, IN 46033

Date 10/16/24

PRODUCT LINE TEST

Test Location Information

Name	FID 13403
Address	603 Colescott St
City	Shelbyville
Phone	
Contact	

Technician Information

Name	Josh Rider
Cert #	UC202406986

Applied Pressure

50 psi

#1 Product Type : Regular

TIME	DATA	+/-	GPL	RES	GPH
1:35pm	74	0	0.0037	0	0
1:50pm	73	-1	0.0037	.0037	.0148
2:05pm	72	-1	0.0037	.0037	.0148
			0.0037		
			0.0037		
			0.0037		
			0.0037		

Final Result : Pass

#2 Product Type : Premium

TIME	DATA	+/-	GPL	RES	GPH
2:15pm	83	0	0.0037	0	0
2:30pm	82	-1	0.0037	.0037	.0148
2:45pm	82	0	0.0037	0	0
			0.0037		
			0.0037		
			0.0037		
			0.0037		

Final Result : Pass

#3 Product Type : Diesel

TIME	DATA	+/-	GPL	RES	GPH
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		

Final Result : .

#4 Product Type :

TIME	DATA	+/-	GPL	RES	GPH
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		

Final Result : .



5296 Breakers Way, Carmel, IN 46033

Date 10/16/24

PRODUCT LINE TEST

Test Location Information

Name	FID 13403
Address	603 Colescott St
City	Shelbyville
Phone	
Contact	

Technician Information

Name	Josh Rider
Cert #	UC202406986

Applied Pressure

50 psi

FINAL REPORT

SR. No.	Product Type	Result
1	Regular	Pass
2	Premium	Pass
3		.
4		.
5		.
6		.

Comment :

Tester's Name : Josh Rider

Tester's Signature : 