

Tanks Data

30 DAYS WALK THROUGH INSPECTION

UST Facility I.D. (FID) #	14983	Contact Number	
Facility Name	MARATHON	Contact email	
Address	46017	Date of Inspection	12/18/27
Operator on Duty Name	Y. W. Mainst, Anderson, Jr	Name of the Person Conducting Inspection	AK SMIT

	Operator Training	Registration/Notification Form	Release Detection	Operator Notified	Yes	No
Operator Training current	☒ Yes	☐ Yes	☐ Yes	Operator Notified	☐ Yes	☐ No
Is Registration current with correct owner, operator etc.	☐ Yes	☐ No	☐ Yes	Operator Notified	☐ Yes	☐ No
Release Detection Method	☒ MTG	☐ MTG	☐ MTG	Operator Notified	☐ Yes	☐ No
Make and Model	MANO	☐ MTG	☐ MTG	Operator Notified	☐ Yes	☐ No
Does it have paper?	☒ Yes	☐ Yes	☐ Yes	Operator Notified	☐ Yes	☐ No
Is it in Alarm mode?	☐ Yes	☐ No	☐ Yes	Operator Notified	☐ Yes	☐ No
Interstitial Monitoring Sensor Status Normal	☐ Yes	☐ No	☐ Yes	Operator Notified	☐ Yes	☐ No
Necessary Monthly Printout Taken	☐ Yes	☐ No	☐ Yes	Operator Notified	☐ Yes	☐ No
Are Spill Buckets Clean and free from water, debris, product etc?	☒ Yes	☐ Yes	☐ Yes	Operator Notified	☐ Yes	☐ No
Are the Spill Bucket in good condition and free of damage/cracks	☒ Yes	☐ Yes	☐ Yes	Operator Notified	☐ Yes	☐ No
Is Fill pipe cap tight and fill pipe free from any obstruction?	☒ Yes	☐ Yes	☐ Yes	Operator Notified	☐ Yes	☐ No
Are Sumps Clean and free from water, debris, product etc?	☒ Yes	☐ Yes	☐ Yes	Operator Notified	☐ Yes	☐ No
Under Dispenser Containments (UDC)	☒ Yes	☐ Yes	☐ Yes	Operator Notified	☐ Yes	☐ No
Are UDCs clean and free from water, debris, product etc?	☒ Yes	☐ Yes	☐ Yes	Operator Notified	☐ Yes	☐ No

NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.

Operator on Duty Name: _____ Signature: _____ Date: _____

317-645-0215 tanksdata@gmail.com www.tanksdata.com