

Site Name : Marathon Service Station
Site Id : 1
Address : 4 W Main Street

SiteSentinel 12-18-2024 12:19 AM

TIMED LEAK TEST

TANK ID : 1
TANK NAME : Unleaded
PRODUCT : Unleaded

START MEASUREMENT

12-17-2024 10:19 PM

PRODUCT LEVEL : 35.0768 IN
AVG PRODUCT TEMP : 45.0282 F
GROSS MEASURED TANK : 2649.5753 gal
NET CORRECTED TANK : 2676.3885 gal

END MEASUREMENT

12-18-2024 12:19 AM

PRODUCT LEVEL : 35.0814 IN
AVG PRODUCT TEMP : 45.3504 F
GROSS MEASURED TANK : 2649.5753 gal
NET CORRECTED TANK : 2676.2920 gal

LEAK RATE

NET TANK LEAK RATE : 0.0483 gal/HR
LEAK RATE THRESHOLD : 0.1000 gal/HR
TEMPERATURE CHANGE : 0.3221 F
TEST DURATION : 120 MIN
VOLUME TESTED : 33.0 % OF TANK VOLUME

TEST RESULT : PASSED