



5296 Breakers Way, Carmel, IN 46033

Date 

11/8/24

## PRODUCT LINE TEST

### Test Location Information

|         |              |
|---------|--------------|
| Name    | FID 14983    |
| Address | 4 W Main St  |
| City    | Chesterfield |
| Phone   |              |
| Contact |              |

### Technician Information

|        |             |
|--------|-------------|
| Name   | Josh Rider  |
| Cert # | UC202406986 |

### Applied Pressure

|        |
|--------|
| 50 psi |
|--------|

### #1 Product Type : Regular

| TIME                | DATA | +/- | GPL    | RES | GPH                                                                                 |
|---------------------|------|-----|--------|-----|-------------------------------------------------------------------------------------|
| 11:55am             | 90   | 0   | 0.0037 | 0   | 0                                                                                   |
| 12:10p              | 90   | 0   | 0.0037 | 0   | 0                                                                                   |
| 12:25p              | 90   | 0   | 0.0037 | 0   | 0                                                                                   |
|                     |      |     | 0.0037 |     |                                                                                     |
|                     |      |     | 0.0037 |     |                                                                                     |
|                     |      |     | 0.0037 |     |                                                                                     |
|                     |      |     | 0.0037 |     |                                                                                     |
| Final Result : Pass |      |     |        |     |  |

### #2 Product Type : Premium

| TIME                | DATA | +/- | GPL    | RES | GPH                                                                                   |
|---------------------|------|-----|--------|-----|---------------------------------------------------------------------------------------|
| 12:40p              | 90   | 0   | 0.0037 | 0   | 0                                                                                     |
| 12:55p              | 90   | 0   | 0.0037 | 0   | 0                                                                                     |
| 1:10pm              | 90   | 0   | 0.0037 | 0   | 0                                                                                     |
|                     |      |     | 0.0037 |     |                                                                                       |
|                     |      |     | 0.0037 |     |                                                                                       |
|                     |      |     | 0.0037 |     |                                                                                       |
|                     |      |     | 0.0037 |     |                                                                                       |
| Final Result : Pass |      |     |        |     |  |

### #3 Product Type : Diesel

| TIME                | DATA | +/- | GPL    | RES | GPH                                                                                 |
|---------------------|------|-----|--------|-----|-------------------------------------------------------------------------------------|
| 1:25pm              | 90   | 0   | 0.0037 | 0   | 0                                                                                   |
| 1:40pm              | 90   | 0   | 0.0037 | 0   | 0                                                                                   |
| 1:55pm              | 90   | 0   | 0.0037 | 0   | 0                                                                                   |
|                     |      |     | 0.0037 |     |                                                                                     |
|                     |      |     | 0.0037 |     |                                                                                     |
|                     |      |     | 0.0037 |     |                                                                                     |
|                     |      |     | 0.0037 |     |                                                                                     |
| Final Result : Pass |      |     |        |     |  |

### #4 Product Type :

| TIME             | DATA | +/- | GPL    | RES | GPH                                                                                   |
|------------------|------|-----|--------|-----|---------------------------------------------------------------------------------------|
|                  |      |     | 0.0037 |     |                                                                                       |
|                  |      |     | 0.0037 |     |                                                                                       |
|                  |      |     | 0.0037 |     |                                                                                       |
|                  |      |     | 0.0037 |     |                                                                                       |
|                  |      |     | 0.0037 |     |                                                                                       |
|                  |      |     | 0.0037 |     |                                                                                       |
|                  |      |     | 0.0037 |     |                                                                                       |
| Final Result : . |      |     |        |     |  |



5296 Breakers Way, Carmel, IN 46033

Date 11/8/24

## PRODUCT LINE TEST

### Test Location Information

|         |              |
|---------|--------------|
| Name    | FID 14983    |
| Address | 4 W Main St  |
| City    | Chesterfield |
| Phone   |              |
| Contact |              |

### Technician Information

|        |             |
|--------|-------------|
| Name   | Josh Rider  |
| Cert # | UC202406986 |

### Applied Pressure

|        |
|--------|
| 50 psi |
|--------|

## FINAL REPORT

| SR. No. | Product Type | Result |
|---------|--------------|--------|
| 1       | Regular      | Pass   |
| 2       | Premium      | Pass   |
| 3       | Diesel       | Pass   |
| 4       |              | .      |
| 5       |              | .      |
| 6       |              | .      |

All three ball valves work very well.

Comment :

Tester's Name : Josh Rider

Tester's Signature : 