

LEAK DETECTOR TEST (DATA SHEET)

Test Location Information

Name	FID 14983
Address	4 W Main St
City	Chesterfield
Phone	
Contact	

Technician Information

Name	Josh Rider
Cert #	UC202406986

TYPE OF LEAK DETECTOR

PRODUCT TYPE	MAKE	MODEL	SERIAL#
Reg	Fe Petro MLLD		
Prem	Fe Petro MLLD		
Dies	Fe Petro MLLD		
Rec-90	European Suction		

Pump #	PRODUCT TYPE	Pump Pressure	Functional Element Holding PSI	Resiliency	Test Leak Rate ML/MIN	Opening Time	Pass/Fail
1	Regular	27	26	90 ml	189ml	3 sec	Pass
2	Premium	27	27	100 ml	189ml	2 sec	Pass
3	Diesel	28	28	140 ml	189ml	5 sec	Pass
4					189ml	.	.
5					189ml	.	.
6					189ml	.	.
7					189ml	.	.
8					189ml	.	.

Comment:

Technician Signature :

