

UST Overfill Equipment Inspection

Automatic Shutoff Device

Sales Rep Email Address

cody@optumpetro.com

Facility Address/City, State, Zip & FID

4 W Main St
Anderson, IN 46017, USA

Testing Company: Optum Petroleum Services

Optum Petroleum Services 5048 W. County Rd 300 N
Frankfort, IN 46041

This data sheet is for inspecting automatic shutoff devices. See PEI/RP1200 Section 7 for inspection procedures.

	1	2	3	4	5
Product Grade	REC				
Tank Volume, gallons	2k				
Tank Number	4				
Tank Diameter, inches	71				
Overfill Prevention Device Brand	Emco				

Automatic Shutoff Device Inspection

	1	2	3	4	5
1. Drop tube removed from tank?	Yes				
2. Drop tube and float mechanisms free of debris?	Yes				
3. Float moves freely without binding and poppet moves into flow path?	Yes				

	1	2	3	4	5
4. Bypass valve in the drop tube open and free of blockage (if present)?	Yes				
5. Flapper adjusted to shut off flow at 95% capacity?*	90%				
Test Results	Pass				
90% or 95%?	90%				

Product Grade

REC

Drop tube height from top to shutoff



Signature