

Tanks Data

30 DAYS WALK THROUGH INSPECTION

UST Facility I.D. (FID) # 14983

Contact Number

Facility Name

Contact email

Address 4 W Main St, Anderson,

Date of Inspection 05-05-25

Operator on Duty Name JW-46017

Name of the Person Conducting Inspection Mohan Singh

Operator Training current

Operator Training

Operator Notified ☐ Yes ☐ No

Is Registration current with correct owner, operator etc.

Registration/Notification Form ☐ Yes ☐ No

Operator Notified ☐ Yes ☐ No

Release Detection Method

Release Detection

Operator Notified ☐ Yes ☐ No

Make and Model

☒ ATG ☐ TIM

Operator Notified ☐ Yes ☐ No

Does it have paper?

☒ Yes ☐ No

Operator Notified ☐ Yes ☐ No

Is it in Alarm mode?

☒ Yes ☐ No

Operator Notified ☐ Yes ☐ No

Interstitial Monitoring Sensor Status Normal

☒ Yes ☐ No

Operator Notified ☐ Yes ☐ No

Necessary Monthly Printout Taken

☒ Yes ☐ No

Operator Notified ☐ Yes ☐ No

Spill Buckets

Operator Notified ☐ Yes ☐ No

Are Spill Buckets Clean and free from water, debris, product etc?

☒ Yes ☐ No

Operator Notified ☐ Yes ☐ No

Are the Spill Bucket in good condition and free of damage/cracks

☒ Yes ☐ No

Operator Notified ☐ Yes ☐ No

Fill Ports

Operator Notified ☐ Yes ☐ No

Is Fill pipe cap tight and fill pipe free from any obstruction?

☒ Yes ☐ No

Operator Notified ☐ Yes ☐ No

Piping/STP Sumps

Operator Notified ☐ Yes ☐ No

Are Sumps Clean and free from water, debris, product etc?

☒ Yes ☐ No

Operator Notified ☐ Yes ☐ No

Under Dispenser Containments (UDC)

Operator Notified ☐ Yes ☐ No

Are UDCs clean and free from water, debris, product etc?

☒ Yes ☐ No

Operator Notified ☐ Yes ☐ No

NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.

Operator on Duty Name

Signature

Date

317-645-0215

tanksdata@gmail.com

www.tanksdata.com

Printer
Not
working