



5296 Breakers Way, Carmel, IN 46033

 www.tanksdata.com
 tanksdata@gmail.com
 (317)-300-6065

Date 11/11/24

LEAK DETECTOR TEST(DATA SHEET)

Test Location Information

Name	FID 10361
Address	2754 E 100 S
City	Anderson
Phone	
Contact	

Technician Information

Name	Josh Rider
Cert #	UC202406986

TYPE OF LEAK DETECTOR

PRODUCT TYPE	MAKE	MODEL	SERIAL#
Reg	Red Jacket MLLD		
Prem	Red Jacket MLLD		
Dies	Red Jacket MLLD		

Pump #	PRODUCT TYPE	Pump Pressure	Functional Element Holding PSI	Resiliency	Test Leak Rate ML/MIN	Opening Time	Pass/Fail
1	Regular	27	26	100 ml	189ml	3 sec	Pass
2	Premium	26	25	90 ml	189ml	2 sec	Pass
3	Diesel	24	24	90 ml	189ml	4 sec	Pass
4					189ml		.
5					189ml		.
6					189ml		.
7					189ml		.
8					189ml		.

Comment:

Technician Signature :

Josh Rider