



5296 Breakers Way, Carmel, IN 46033

www.tanksdata.com
tanksdata@gmail.com
(317)-300-6065

Date 09/09/2025

UST OVERFILL EQUIPMENT INSPECTION AUTOMATIC SHUTOFF DEVICE AND BALL FLOAT VALVE

Facility Name:	Marathon	Owner:	Ms Petro
Address:	2754 E 100 S	Address:	2754 E 100 S
City, State, Zip Code:	Anderson, IN 46017	City, State, Zip Code:	Anderson, IN 46017
Facility I.D. #:	10361	Phone #:	

This data sheet is for inspecting automatic shutoff devices and ball float valves. See PEI/RP1200 Section 7 for inspection procedures.

Product Grade	Regular	Premium				
Tank Number	1	2				
Tank Volume, gallons	10,000	6,000				
Tank Diameter, inches	90	95				
Overfill Prevention Device Brand	EMCO	EMCO				
Type of Overfill Device	ASD	ASD				

AUTOMATIC SHUTOFF DEVICE INSPECTION

1. Drop tube removed from tank?	Yes	Yes				
2. Drop tube and float mechanisms free of debris?	Yes	Yes				
3. Float moves freely without binding and poppet moves into flow path?	Yes	Yes				
4. Bypass valve in the drop tube open and free of blockage (if present)?	Yes	Yes				
5. Flapper adjusted to shut off flow at 95% capacity?*	Yes	Yes				
6. Is Ball Float Present?						
7. Measured Auto Shut-Off Level	86	81				

A "No" to any item in Lines 1-5 indicates a test failure.

BALL FLOAT VALVE INSPECTION

1. Tank top fittings vapor- tight and leak-free?						
2. Ball float cage free of debris?						
3. Ball free of holes and cracks and moves freely in cage?						
4. Vent hole in pipe open and near top of tank?						
5. Ball float pipe proper length to restrict flow at 90% capacity?*						
6. Ball Float removed from the tank?						
7. Ball Float Level						

A "No" to any item in Lines 1-5 indicates a test failure.

Test Results	Pass	Pass				
--------------	------	------	--	--	--	--

Comment: Cut and replaced coaxial adaptor for Reg and Prem

* Use manufacturer's suggested procedure for determining if automatic shutoff device will shut off flow at 95% capacity.
** Use manufacturer's suggested procedure for determining if flow restriction device will restrict flow at 90% capacity.

Tester's Name : Virender Kumar

Tester's Signature :