

TANK LEAK TEST HISTORY

T 2:REGULAR

LAST GROSS TEST PASSED:
JUN 29, 2025 12:00 AM
STARTING VOLUME = 241
PERCENT VOLUME = 4.0
TEST TYPE = STANDARD

LAST ANNUAL TEST PASSED:
JUN 28, 2025 12:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME = 281
PERCENT VOLUME = 4.7
TEST TYPE = STANDARD

FULLEST ANNUAL TEST PASS
MAY 17, 2025 12:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME = 1130
PERCENT VOLUME = 18.8
TEST TYPE = STANDARD

LAST PERIODIC TEST PASS:
JUN 29, 2025 12:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME = 241
PERCENT VOLUME = 4.0
TEST TYPE = STANDARD

FULLEST PERIODIC TEST PASSED EACH MONTH:

JAN 27, 2025 12:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME = 1108
PERCENT VOLUME = 18.4
TEST TYPE = STANDARD

FEB 1, 2025 12:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME = 1000
PERCENT VOLUME = 16.6
TEST TYPE = STANDARD

MAR 28, 2025 12:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME = 1108
PERCENT VOLUME = 18.4
TEST TYPE = STANDARD

APR 1, 2025 12:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME = 1040
PERCENT VOLUME = 17.3
TEST TYPE = STANDARD

MAY 17, 2025 12:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME = 1130
PERCENT VOLUME = 18.8
TEST TYPE = STANDARD

JUN 2, 2025 12:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME = 862
PERCENT VOLUME = 14.3
TEST TYPE = STANDARD

JUL 23, 2024 12:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME = 483
PERCENT VOLUME = 8.0
TEST TYPE = STANDARD

AUG 5, 2024 12:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME = 1131
PERCENT VOLUME = 18.8
TEST TYPE = STANDARD

SEP 15, 2024 12:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME = 1081
PERCENT VOLUME = 18.0
TEST TYPE = STANDARD

OCT 20, 2024 12:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME = 1118
PERCENT VOLUME = 18.6
TEST TYPE = STANDARD

NOV 1, 2024 12:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME = 829
PERCENT VOLUME = 13.8
TEST TYPE = STANDARD

DEC 8, 2024 12:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME = 1125
PERCENT VOLUME = 18.7
TEST TYPE = STANDARD

TANK LEAK TEST HISTORY

T 3:REGULAR

LAST GROSS TEST PASSED:
JUL 3, 2025 12:00 AM
STARTING VOLUME = 4937
PERCENT VOLUME = 48.6
TEST TYPE = STANDARD

LAST ANNUAL TEST PASSED:
JUL 3, 2025 12:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME = 4937
PERCENT VOLUME = 48.6
TEST TYPE = STANDARD

FULLEST ANNUAL TEST PASS
APR 28, 2025 12:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME = 5964
PERCENT VOLUME = 58.7
TEST TYPE = STANDARD

LAST PERIODIC TEST PASS:
JUL 3, 2025 12:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME = 4937
PERCENT VOLUME = 48.6
TEST TYPE = STANDARD

FULLEST PERIODIC TEST PASSED EACH MONTH:

JAN 3, 2025 12:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME = 4834
PERCENT VOLUME = 47.6
TEST TYPE = STANDARD

FEB 26, 2025 12:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME = 4650
PERCENT VOLUME = 45.8
TEST TYPE = STANDARD

MAR 10, 2025 12:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME = 4927
PERCENT VOLUME = 48.5
TEST TYPE = STANDARD

APR 28, 2025 12:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME = 5964
PERCENT VOLUME = 58.7
TEST TYPE = STANDARD

MAY 6, 2025 12:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME = 4515
PERCENT VOLUME = 44.5
TEST TYPE = STANDARD

JUN 5, 2025 12:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME = 5622
PERCENT VOLUME = 54.4
TEST TYPE = STANDARD

JUL 2, 2025 12:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME = 5535
PERCENT VOLUME = 54.5
TEST TYPE = STANDARD

AUG 21, 2024 12:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME = 4392
PERCENT VOLUME = 43.3
TEST TYPE = STANDARD

SEP 19, 2024 12:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME = 5750
PERCENT VOLUME = 56.6
TEST TYPE = STANDARD

OCT 9, 2024 12:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME = 4182
PERCENT VOLUME = 41.2
TEST TYPE = STANDARD

NOV 4, 2024 12:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME = 4390
PERCENT VOLUME = 43.2
TEST TYPE = STANDARD

DEC 26, 2024 12:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME = 4862
PERCENT VOLUME = 47.9
TEST TYPE = STANDARD

TANK LEAK TEST HISTORY

T 1:DIESEL

LAST GROSS TEST PASSED:
JUL 3, 2025 12:00 AM
STARTING VOLUME= 960
PERCENT VOLUME = 16.0
TEST TYPE = STANDARD

LAST ANNUAL TEST PASSED:
JUL 3, 2025 12:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME= 960
PERCENT VOLUME = 16.0
TEST TYPE = STANDARD

FULLEST ANNUAL TEST PASS
MAY 14, 2025 12:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME= 1219
PERCENT VOLUME = 20.3
TEST TYPE = STANDARD

LAST PERIODIC TEST PASS:
JUL 3, 2025 12:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME= 960
PERCENT VOLUME = 16.0
TEST TYPE = STANDARD

FULLEST PERIODIC TEST
PASSED EACH MONTH:

JAN 1, 2025 12:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME= 1152
PERCENT VOLUME = 19.2
TEST TYPE = STANDARD

FEB 2, 2025 12:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME= 647
PERCENT VOLUME = 10.8
TEST TYPE = STANDARD

MAR 7, 2025 12:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME= 1197
PERCENT VOLUME = 19.9
TEST TYPE = STANDARD

APR 9, 2025 12:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME= 1098
PERCENT VOLUME = 18.3
TEST TYPE = STANDARD

MAY 14, 2025 12:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME= 1219
PERCENT VOLUME = 20.3
TEST TYPE = STANDARD

JUN 29, 2025 12:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME= 1083
PERCENT VOLUME = 18.0
TEST TYPE = STANDARD

JUL 1, 2025 12:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME= 1006
PERCENT VOLUME = 16.7
TEST TYPE = STANDARD

AUG 1, 2024 12:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME= 1196
PERCENT VOLUME = 19.9
TEST TYPE = STANDARD

SEP 10, 2024 12:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME= 1186
PERCENT VOLUME = 19.7
TEST TYPE = STANDARD

\$T 29, 2024 12:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME= 1364
PERCENT VOLUME = 22.7
TEST TYPE = STANDARD

NOV 2, 2024 12:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME= 1252
PERCENT VOLUME = 20.8
TEST TYPE = STANDARD

DEC 22, 2024 12:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME= 1286
PERCENT VOLUME = 21.4
TEST TYPE = STANDARD

LIQUID STATUS

JUL 3, 2025 4:51 PM

NONE

LEAK TEST REPORT

T 1:DIESEL

TEST STARTING TIME:

JUL 3, 2025 12:00 AM

TEST LENGTH 4 HOURS

STARTING TEMP = 68.2 F

ENDING TEMP = 68.2 F

LEAK TEST RESULTS

0.2 GAL/HR TEST PASS

LEAK TEST REPORT

T 2:PREM.

TEST STARTING TIME:

JUL 3, 2025 12:00 AM

TEST LENGTH 4 HOURS

STARTING TEMP = 68.6 F

ENDING TEMP = 68.7 F

LEAK TEST RESULTS

0.2 GAL/HR TEST INVALID

0.2 GAL/HR FLAGS:

LOW LEVEL TEST ERROR

INVALID FUEL LEVEL

LEAK TEST REPORT

T 3:REGULAR

TEST STARTING TIME:

JUL 3, 2025 12:00 AM

TEST LENGTH 4 HOURS

STARTING TEMP = 70.8 F

ENDING TEMP = 70.7 F

LEAK TEST RESULTS

0.2 GAL/HR TEST PASS