

06/26/25 6:56 PM

Bristol Amoco
1110 Mottville Road
Bristol, IN 46507

TANK LEAK TEST HISTORY -
PASSED TEST RESULTS

T 1: Regular Unlead

REPORT TYPE = LAST GROSS
DATE/TIME = 06/26/25 1:53
METHOD = SLD Gross Test
AVG. VOLUME = 8378
% VOLUME = 50.4

REPORT TYPE = LAST PERIODIC
DATE/TIME = 06/26/25 2:46
METHOD = CSLD Periodic Test
HOURS = 23
AVG. VOLUME = 7923
% VOLUME = 47.7

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 06/23/25 3:49
METHOD = CSLD Periodic Test
HOURS = 21
AVG. VOLUME = 9067
% VOLUME = 54.5

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 05/12/25 3:51
METHOD = CSLD Periodic Test
HOURS = 24
AVG. VOLUME = 11090
% VOLUME = 66.7

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 04/29/25 4:04
METHOD = CSLD Periodic Test
HOURS = 29
AVG. VOLUME = 10612
% VOLUME = 63.8

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 03/01/25 1:27
METHOD = CSLD Periodic Test
HOURS = 23
AVG. VOLUME = 9483
% VOLUME = 57.1

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 02/28/25 3:35
METHOD = CSLD Periodic Test
HOURS = 22
AVG. VOLUME = 9500
% VOLUME = 57.2

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 01/01/25 5:10
METHOD = CSLD Periodic Test
HOURS = 10
AVG. VOLUME = 11353
% VOLUME = 68.3

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 12/31/24 6:05
METHOD = CSLD Periodic Test
HOURS = 10
AVG. VOLUME = 11353
% VOLUME = 68.3

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 11/30/24 15:46
METHOD = CSLD Periodic Test
HOURS = 36
AVG. VOLUME = 8099
% VOLUME = 48.7

06/26/25 6:56 PM

Bristol Amoco
1110 Mottville Road
Bristol, IN 46507

PRESSURE LINE LEAK REPORTS
PASSED TESTS HISTORY

Ln 1: RUL

Gross Test
Prev 24 Hours 56
Since Midnight 46

Last Gross 06/26/25 6:34 PM

Ln 2: Premium

Gross Test
Prev 24 Hours 99
Since Midnight 89

Last Gross 06/26/25 6:55 PM

Ln 3: Rec 90

Gross Test
Prev 24 Hours 3
Since Midnight 3

Last Gross 06/26/25 1:52 PM

Last Periodic 06/04/25 1:11 PM

First Periodic 06/04/25 1:11 PM

Ln 4: Diesel

Gross Test
Prev 24 Hours 28
Since Midnight 24

Last Gross 06/26/25 5:30 PM

Last Periodic 06/20/25 11:44 PM

Last Annual 06/21/25 12:32 AM

First Periodic 06/05/25 1:10 AM

First Annual 06/21/25 12:32 AM

Ln 5: DEF

METHOD = 29
 HOURS = 10612
 AVG. VOLUME = 63.8
 % VOLUME
 REPORT TYPE = FULLEST PERIODIC
 DATE/TIME = 03/01/25 1:27
 METHOD = CSLD Periodic Test
 HOURS = 23
 AVG. VOLUME = 9483
 % VOLUME = 57.1
 REPORT TYPE = FULLEST PERIODIC
 DATE/TIME = 02/28/25 3:35
 METHOD = CSLD Periodic Test
 HOURS = 22
 AVG. VOLUME = 9500
 % VOLUME = 57.2
 REPORT TYPE = FULLEST PERIODIC
 DATE/TIME = 01/01/25 5:10
 METHOD = CSLD Periodic Test
 HOURS = 10
 AVG. VOLUME = 11353
 % VOLUME = 68.3
 REPORT TYPE = FULLEST PERIODIC
 DATE/TIME = 12/31/24 6:05
 METHOD = CSLD Periodic Test
 HOURS = 10
 AVG. VOLUME = 11353
 % VOLUME = 68.3
 REPORT TYPE = FULLEST PERIODIC
 DATE/TIME = 11/30/24 15:46
 METHOD = CSLD Periodic Test
 HOURS = 36
 AVG. VOLUME = 8099
 % VOLUME = 48.7

06/26/25 6:56 PM

Bristol Amoco
 1110 Mottville Road
 Bristol, IN 46507

PRESSURE LINE LEAK REPORTS PASSED TESTS HISTORY

Ln 1: RUL

Gross Test
 Prev 24 Hours 56
 Since Midnight 46

Last Gross 06/26/25 6:34 PM

Ln 2: Premium

Gross Test
 Prev 24 Hours 99
 Since Midnight 89

Last Gross 06/26/25 6:55 PM

Ln 3: Rec 90

Gross Test
 Prev 24 Hours 3
 Since Midnight 3

Last Gross 06/26/25 1:52 PM

Last Periodic 06/04/25 1:11 PM

First Periodic 06/04/25 1:11 PM

Ln 4: Diesel

Gross Test
 Prev 24 Hours 28
 Since Midnight 24

Last Gross 06/26/25 5:30 PM

Last Periodic 06/20/25 11:44 PM

Last Annual 06/21/25 12:32 AM

First Periodic 06/05/25 1:10 AM

First Annual 06/21/25 12:32 AM

Ln 5: DEF

06/26/25 6:56 PM

Bristol Amoco
 1110 Mottville Road
 Bristol, IN 46507

Active Alarm Report

ID	=	T	4
LABEL	=	Diesel	
DESCRIPTION	=	DELIVERY NEEDED	
ACTIVE	=	06/25/25	2:01P
CLEAR	=	06/26/25	1:59P

ID	=	T	1
LABEL	=	Regular Unlead	
DESCRIPTION	=	DELIVERY NEEDED	
ACTIVE	=	06/24/25	5:40P
CLEAR	=	06/25/25	6:45A

ID	=	P	1
LABEL	=		
DESCRIPTION	=	PRINTER ERROR	
ACTIVE	=	06/13/25	8:38A
CLEAR	=	06/13/25	8:39A

ID	=	P	1
LABEL	=		
DESCRIPTION	=	PAPER OUT	
ACTIVE	=	06/13/25	8:38A
CLEAR	=	06/13/25	8:39A

ID	=	T	1
LABEL	=	Regular Unlead	
DESCRIPTION	=	LOW PRODUCT ALARM	
ACTIVE	=	06/05/25	2:32P
CLEAR	=	06/05/25	2:36P

ID	=	T	4
LABEL	=	Diesel	
DESCRIPTION	=	GROSS FAIL LINE TNK	
ACTIVE	=	05/02/25	4:03P
CLEAR	=	05/02/25	5:11P

ID	=	L	18
LABEL	=	Disp 16 Pan	
DESCRIPTION	=	FUEL ALARM	
ACTIVE	=	03/19/25	5:26P
CLEAR	=		