

03/23/25 6:29 PM

Aristol Amoco  
110 Mottville Road  
Aristol, IN 46507

Sensor Status Report - All Sensors

| Sensor Location    | Status     |
|--------------------|------------|
| 1 RUL STP Sump     | NORMAL     |
| 2 Premium STP Sump | NORMAL     |
| 3 Rec 90 STP Sump  | NORMAL     |
| 4 Diesel STP Sump  | NORMAL     |
| 5 DEF STP Sump     | NORMAL     |
| 6 RUL.Prem INT     | NORMAL     |
| 7 REC.DSL INT      | NORMAL     |
| 8 DEF Interstitial | NORMAL     |
| 9 Disp 1.2 Pan     | NORMAL     |
| 10 Disp 3.4 pan    | NORMAL     |
| 11 Disp 5.6 Pan    | NORMAL     |
| 12 Disp 7.8 Pan    | NORMAL     |
| 13 Disp 9.10 Pan   | NORMAL     |
| 14 Disp 11.12 Pan  | NORMAL     |
| 15 Disp 13 Pan     | NORMAL     |
| 16 Disp 14 Pan     | NORMAL     |
| 17 Disp 15 Pan     | NORMAL     |
| 18 Disp 16 Pan     | FUEL ALARM |

03/23/25 6:29 PM

Aristol Amoco  
110 Mottville Road  
Aristol, IN 46507

PRESSURE LINE LEAK REPORTS

PASSED TESTS HISTORY

1: RUL

Cross Test

Prev 24 Hours 50  
Since Midnight 42

Last Gross 03/23/25 6:07 PM  
Last Periodic 03/03/25 1:28 AM

First Periodic 03/03/25 1:28 AM

2: Premium

Cross Test

Prev 24 Hours 57  
Since Midnight 49

Last Gross 03/23/25 6:29 PM  
Last Periodic 03/04/25 1:45 AM

First Periodic 03/04/25 1:45 AM

3: Rec 90

Cross Test

Prev 24 Hours 1  
Since Midnight 0

Last Gross 03/22/25 7:59 PM  
Last Periodic 03/02/25 4:27 PM

First Periodic 03/02/25 4:27 PM

4: Diesel

Cross Test

Prev 24 Hours 7  
Since Midnight 7

Last Gross 03/23/25 2:50 PM  
Last Periodic 03/04/25 11:15 AM

First Periodic 03/04/25 11:15 AM

5: DEF

03/23/25 6:29 PM

Bristol Amoco  
10 Mottville Road  
Bristol, IN 46507

PRESSURE LINE LEAK REPORTS  
PASSED TESTS HISTORY

1: RUL

Gross Test  
Prev 24 Hours 50  
Since Midnight 42

Last Gross 03/23/25 6:07 PM  
Last Periodic 03/03/25 1:28 AM

First Periodic 03/03/25 1:28 AM

03/23/25 6:30 PM

Bristol Amoco  
10 Mottville Road  
Bristol, IN 46507

PRESSURE LINE LEAK REPORTS  
PASSED TESTS HISTORY

2: Premium

Gross Test  
Prev 24 Hours 57  
Since Midnight 49

Last Gross 03/23/25 6:29 PM  
Last Periodic 03/04/25 1:45 AM

First Periodic 03/04/25 1:45 AM

03/23/25 6:30 PM

Bristol Amoco  
110 Mottville Road  
Bristol, IN 46507

PRESSURE LINE LEAK REPORTS  
PASSED TESTS HISTORY

3: Rec 90

Gross Test  
Prev 24 Hours 1  
Since Midnight 0

Last Gross 03/22/25 7:59 PM  
Last Periodic 03/02/25 4:27 PM

First Periodic 03/02/25 4:27 PM

03/23/25 6:31 PM

Bristol Amoco  
110 Mottville Road  
Bristol, IN 46507

PRESSURE LINE LEAK REPORTS  
PASSED TESTS HISTORY

4: Diesel

Gross Test  
Prev 24 Hours 7  
Since Midnight 7

Last Gross 03/23/25 2:50 PM  
Last Periodic 03/04/25 11:15 AM

First Periodic 03/04/25 11:15 AM