

07/23/25 5:49 PM

Bristol Amoco
1110 Mottville Road
Bristol, IN 46507

PRESSURE LINE LEAK REPORTS PASSED TESTS HISTORY

Ln 1: RUL

Gross Test
Prev 24 Hours 54
Since Midnight 40
Last Gross 07/23/25 5:37 PM

Ln 2: Premium

Gross Test
Prev 24 Hours 99
Since Midnight 81
Last Gross 07/23/25 5:47 PM

Ln 3: Rec 90

Gross Test
Prev 24 Hours 5
Since Midnight 4
Last Gross 07/23/25 4:45 PM
Last Periodic 07/02/25 12:42 PM
First Periodic 07/02/25 12:42 PM

Ln 4: Diesel

Gross Test
Prev 24 Hours 31
Since Midnight 28
Last Gross 07/23/25 5:17 PM
Last Periodic 07/16/25 11:07 PM
First Periodic 07/16/25 11:07 PM

Ln 5: DEF

07/23/25 5:49 PM

Bristol Amoco
1110 Mottville Road
Bristol, IN 46507

TANK LEAK TEST HISTORY - PASSED TEST RESULTS

T 1: Regular Unlead

REPORT TYPE = LAST GROSS
DATE/TIME = 07/23/25 2:34
METHOD = SLD Gross Test
AVG. VOLUME = 5880
% VOLUME = 35.4

REPORT TYPE = LAST PERIODIC
DATE/TIME = 07/23/25 3:06
METHOD = CSLD Periodic Test
HOURS = 23
AVG. VOLUME = 8573
% VOLUME = 51.6

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 07/15/25 3:27
METHOD = CSLD Periodic Test
HOURS = 24
AVG. VOLUME = 8819
% VOLUME = 53.1

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 06/23/25 3:49
METHOD = CSLD Periodic Test
HOURS = 21
AVG. VOLUME = 9067
% VOLUME = 54.5

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 05/12/25 3:51
METHOD = CSLD Periodic Test
HOURS = 24
AVG. VOLUME = 11090
% VOLUME = 66.7

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 04/29/25 4:04
METHOD = CSLD Periodic Test
HOURS = 29
AVG. VOLUME = 10612
% VOLUME = 63.8

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 03/01/25 1:27
METHOD = CSLD Periodic Test
HOURS = 23
AVG. VOLUME = 9483
% VOLUME = 57.1

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 02/28/25 3:35
METHOD = CSLD Periodic Test
HOURS = 22
AVG. VOLUME = 9500
% VOLUME = 57.2

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 01/01/25 5:10
METHOD = CSLD Periodic Test
HOURS = 10
AVG. VOLUME = 11353
% VOLUME = 68.3

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 12/31/24 6:05
METHOD = CSLD Periodic Test
HOURS = 10
AVG. VOLUME = 11353
% VOLUME = 68.3

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 11/30/24 15:46
METHOD = CSLD Periodic Test
HOURS = 36
AVG. VOLUME = 8099
% VOLUME = 48.7

07/23/25 5:49 PM

Bristol Amoco
1110 Mottville Road
Bristol, IN 46507

Sensor Status Report - All Sensors

#	Sensor Location	Status
L 1	RUL STP Sump	NORMAL
L 2	Premium STP Sump	NORMAL
L 3	Rec 90 STP Sump	NORMAL
L 4	Diesel STP Sump	NORMAL
L 5	DEF STP Sump	NORMAL
L 6	RUL Prem INT	NORMAL
L 7	REC.DSL INT	NORMAL
L 8	DEF Interstitial	NORMAL
L 9	Disp 1.2 Pan	NORMAL
L 10	Disp 3.4 Pan	NORMAL
L 11	Disp 5.6 Pan	NORMAL
L 12	Disp 7.8 Pan	NORMAL
L 13	Disp 9.10 Pan	NORMAL
L 14	Disp 11.12 Pan	NORMAL
L 15	Disp 13 Pan	NORMAL
L 16	Disp 14 Pan	NORMAL
L 17	Disp 15 Pan	NORMAL
L 18	Disp 16 Pan	FUEL ALARM