

08/24/25 4:30 PM

Bristol Amoco
1110 Mottville Road
Bristol, IN 46507

PRESSURE LINE LEAK REPORTS
PASSED TESTS HISTORY

Ln 1: RUL

Gross Test
Prev 24 Hours 59
Since Midnight 39

Last Gross 08/24/25 4:14 PM

Ln 2: Premium

Gross Test
Prev 24 Hours 76
Since Midnight 54

Last Gross 08/24/25 4:23 PM

Ln 3: Rec 90

Gross Test
Prev 24 Hours 7
Since Midnight 6

Last Gross 08/24/25 3:21 PM

Last Periodic 08/05/25 10:43 AM

Last Annual 08/15/25 6:51 AM

First Periodic 08/01/25 10:13 AM

First Annual 08/15/25 6:51 AM

Ln 4: Diesel

Gross Test
Prev 24 Hours 8
Since Midnight 5

Last Gross 08/24/25 12:56 PM

Last Periodic 08/05/25 7:19 PM

First Periodic 08/05/25 7:19 PM

Ln 5: DEF

08/24/25 4:30 PM

Bristol Amoco
1110 Mottville Road
Bristol, IN 46507

Sensor Status Report - All Sensors

#	Sensor Location	Status
L 1	RUL STP Sump	NORMAL
L 2	Premium STP Sump	NORMAL
L 3	Rec 90 STP Sump	NORMAL
L 4	Diesel STP Sump	NORMAL
L 5	DEF STP Sump	NORMAL
L 6	RUL, Prem INT	NORMAL
L 7	REC, DSL INT	NORMAL
L 8	DEF Interstitial	NORMAL
L 9	Disp 1.2 Pan	NORMAL
L 10	Disp 3.4 pan	NORMAL
L 11	Disp 5.6 Pan	NORMAL
L 12	Disp 7.8 Pan	NORMAL
L 13	Disp 9.10 Pan	NORMAL
L 14	Disp 11.12 Pan	NORMAL
L 15	Disp 13 Pan	NORMAL
L 16	Disp 14 Pan	NORMAL
L 17	Disp 15 Pan	FUEL ALARM
L 18	Disp 16 Pan	FUEL ALARM