

09/30/25 2:19 AM
Bristol Amoco
1110 Mottville Road
Bristol, IN 46507

TANK LEAK TEST HISTORY -
PASSED TEST RESULTS

T 1: Regular Unlead

REPORT TYPE = LAST GROSS
DATE/TIME = 09/29/25 14:42
METHOD = SLD Gross Test
AVG. VOLUME = 9708
% VOLUME = 58.4

REPORT TYPE = LAST PERIODIC
DATE/TIME = 09/10/25 1:31
METHOD = CSLD Periodic Test
HOURS = 23
AVG. VOLUME = 9087
% VOLUME = 54.7

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 09/05/25 0:34
METHOD = CSLD Periodic Test
HOURS = 25
AVG. VOLUME = 9319
% VOLUME = 56.1

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 08/12/25 3:13
METHOD = CSLD Periodic Test
HOURS = 23
AVG. VOLUME = 10858
% VOLUME = 65.3

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 07/29/25 3:05
METHOD = CSLD Periodic Test
HOURS = 21
AVG. VOLUME = 9440
% VOLUME = 56.8

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 06/23/25 3:49
METHOD = CSLD Periodic Test
HOURS = 21
AVG. VOLUME = 9067
% VOLUME = 54.5

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 05/12/25 3:51
METHOD = CSLD Periodic Test
HOURS = 24
AVG. VOLUME = 11090
% VOLUME = 66.7

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 04/29/25 4:04
METHOD = CSLD Periodic Test
HOURS = 29
AVG. VOLUME = 10612
% VOLUME = 63.8

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 03/01/25 1:27
METHOD = CSLD Periodic Test
HOURS = 23
AVG. VOLUME = 9483
% VOLUME = 57.1

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 02/28/25 3:35
METHOD = CSLD Periodic Test
HOURS = 22
AVG. VOLUME = 9500
% VOLUME = 57.2

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 01/01/25 5:10
METHOD = CSLD Periodic Test
HOURS = 10
AVG. VOLUME = 11353
% VOLUME = 68.3

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 12/31/24 6:05
METHOD = CSLD Periodic Test
HOURS = 10
AVG. VOLUME = 11353
% VOLUME = 68.3

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 11/30/24 15:46
METHOD = CSLD Periodic Test
HOURS = 36
AVG. VOLUME = 8099
% VOLUME = 48.7

09/30/25 2:19 AM

Bristol Amoco
1110 Mottville Road
Bristol, IN 46507

PRESSURE LINE LEAK REPORTS
PASSED TESTS HISTORY

T 1: RUL

Gross Test
Prev 24 Hours 59
Since Midnight 8

Last Gross 09/30/25 2:00 AM

T 2: Premium

Gross Test
Prev 24 Hours 79
Since Midnight 9

Last Gross 09/30/25 2:11 AM

T 3: Rec 90

Gross Test
Prev 24 Hours 5
Since Midnight 2

Last Gross 09/30/25 1:46 AM

Last Periodic 09/26/25 11:08 PM

First Periodic 09/22/25 5:39 PM

T 4: Diesel

Gross Test
Prev 24 Hours 32
Since Midnight 6

Last Gross 09/30/25 2:18 AM

Last Periodic 09/26/25 5:25 PM

First Periodic 09/02/25 9:56 PM

T 5: DEF

09/30/25 2:20 AM

Bristol Amoco
1110 Mottville Road
Bristol, IN 46507

Sensor Status Report - All Sensors

Sensor Location	Status
1 RUL STP Sump	NORMAL
2 Premium STP Sump	NORMAL
3 Rec 90 STP Sump	NORMAL
4 Diesel STP Sump	NORMAL
5 DEF STP Sump	NORMAL
6 RUL Prem INT	NORMAL
7 REC DSL INT	NORMAL
8 DEF Interstitial	NORMAL
9 Disp 1.2 Pan	NORMAL
10 Disp 3.4 Pan	NORMAL
11 Disp 5.6 Pan	NORMAL
12 Disp 7.8 Pan	NORMAL
13 Disp 9.10 Pan	NORMAL
14 Disp 11.12 Pan	NORMAL
15 Disp 13 Pan	NORMAL
16 Disp 4 Pan	FUEL ALARM
17 Disp 15 Pan	FUEL ALARM
18 Disp 16 Pan	