Facility #:	7606
•	

Facility Address: 3479 Georgia St. Gary, IN 46409



Annual Walkthrough Inspection Report: 20²⁴ (year)

Inspections Required Annually (Inspections of piping sump areas must be performed by a certified employee of a contractor licensed in either the Install/Retrofit or Tank Tightness Testing modules.) All piping sumps areas shall be checked annually. Sump lids must be lifted and dispenser cabinets opened to inspect piping containment sump areas.

Contractor must initial and enter date of Annual Walkthrough Inspection.	Day/Month/Year of Inspection	Contractor Initials	Enter comments below corresponding to inspections listed at left.
Visual check for damage to piping containment sump areas: Check lids, covers & containment for damage & leaks.	1/25/24	CZ	COMMENTS & ACTIONS TAKEN: Covers are cracked
Check sumps for the presence of regulated substances or any indication that a release may have occurred. Remove any liquid or debris if present.	1/25/24	CZ	COMMENTS & ACTIONS TAKEN: Liquid in multiple sumps.
Check that interstices of double wall containment sumps are free of water or product.	N/A		COMMENTS & ACTIONS TAKEN:
If applicable: Check gauge stick (manual tank gauging) or bailer (GW monitoring).	N/A		COMMENTS & ACTIONS TAKEN:

Chris Zell
Chris Zell 1) Signature:

2) Print Name & Title:

Contractor Employee Conducting Annual Inspection of Piping Containment Sump Areas:

Annual Test & Inspection: May be Performed by Contractor or A/B Operator

Contractor or A/B	Day/Month/Year of	Contractor or A/B	Enter comments below regarding Annual		
Operator must initial and	Emergency Stop Test	Operator Initials	Emergency Stops Test. Attach OSFM Operational		
enter date of Annual	1/25/24	CZ	Testing of Emergency Stops Report to Walkthrough		
Emergency Stops Test.	1/25/24		Inspection Report & keep at facility.		
Test Emergency Stops for	COMMENTS:				
interconnection and STP	Works but needs labeled.				
shutdown.					
Attach OSFM report form.					
Contractor or A/B	Day/Month/Year of	Contractor or A/B	Enter comments below regarding Annual Shear		
Operator must initial and	Shear Valve Inspection	Operator Initials	Valve Inspection. Attach OSFM Annual Inspection		
enter date of Annual Shear	1/25/24	CZ	of Shear Valves Report to Walkthrough Inspection		
Valve Inspection.	1/23/24		Report & keep at facility.		
Check shear valves for	COMMENTS:				
proper height, secure	Good				
mounting & free operation					
of trip arm & poppet.					

A/B Operator Signature (if applicable):	
Print Name of A/B Operator (if applicable):	