

 Midwest Tank Testing AN ENVIRONMENTAL COMPLIANCE COMPANY 316 W. Indiana Ave. Chesterton, IN 46304 REVISION 8/21/2019				EZY CHEK SYSTEMS LEAK DETECTOR TEST		DATE AND TIME 1/25/24 - 11:30-12:50		
				WEATHER 40 Cloudy				
				COLLECT/INVOICE Collected				
				CLIENT EMAIL -				
Testing Company Information						Name Midwest Tank Testing		
Test Location Information				Certifications		Address 316 W. Indiana Ave.		
PC # and WO #				Estabrooks: 82-1906		City/State/Zip Chesterton, IN 46304		
Name and FID #		GoLo - FID 7606		ICC: 10221928		Phone 800-975-1436		
Address		3479 Georgia St		Indiana: UC 110386		Technician Information		
City/State/Zip		Gary, IN 46404		CP/STI: 16655		Name Chris Zell		
Contact				UC111023		Email support@midwesttanktesting.com		
Phone				UC111987				
TYPE OF LEAK DETECTOR - (LD) or (ELD)								
PUMP #		PRODUCT		MODEL		SERIAL # (If Legible)		
1		Regular		Red Jacket/FePetro		N/A		
2		Premium		Red Jacket/FePetro		N/A		
3								
4								
5								
6								
7								
8								
LEAK DETECTOR TEST								
PUMP #		Product Type	Metering Pressure	Functional Element Holding PSI	Resiliency	Test Leak Rate ML/MIN	Opening Time	Results
1		Regular	30	17	130	189ml	2	Pass
2		Premium	25	15	100	189ml	1	Pass
3						189ml		
4						189ml		
5						189ml		
6						189ml		
7						189ml		
8						189 ml		
COMMENTS/RECOMMENDATIONS:								

Test Location Information

PC # and WO #	
Name and FID #	GoLo - FID 7606
Address	3479 Georgia St
City/State/Zip	Gary, IN 46404
Contact	
Phone	

Testing Company Information

Name	Midwest Tank Testing
Address	316 W. Indiana Ave.
City/State/Zip	Chesterton, IN 46304
Phone	800-975-1436

Technician Information

Name	Chris Zell
Email	support@midwesttanktesting.com
Applied Pressure	1-1/2 Times Working Pressure, Min 50 PSI

PRODUCT LINE TEST - DATA (LT)

#1	Product Type:		Regular		
TIME	DATA	-/+	GPL	RES	GPH
11:50	71	0	0.0037	0.0000	0.0000
12:05	68	-3	0.0037	-0.0111	-0.0444
12:20	65	-3	0.0037	-0.0111	-0.0444
12:35	62	-3	0.0037	-0.0111	-0.0444
		0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
FINAL RESULT:			Pass		

#2	Product Type:		Premium		
TIME	DATA	-/+	GPL	RES	GPH
11:50	90	0	0.0037	0.0000	0.0000
12:05	90	0	0.0037	0.0000	0.0000
12:20	90	0	0.0037	0.0000	0.0000
12:35	90	0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
FINAL RESULT:			Pass		

#3	Product Type:				
TIME	DATA	-/+	GPL	RES	GPH
		0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
FINAL RESULT:					

#4	Product Type:				
TIME	DATA	-/+	GPL	RES	GPH
		0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
FINAL RESULT:					

#5	Product Type:				
TIME	DATA	-/+	GPL	RES	GPH
		0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
FINAL RESULT:					

#6	Product Type:				
TIME	DATA	-/+	GPL	RES	GPH
		0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
FINAL RESULT:					

COMMENTS/RECOMMENDATIONS:



INDIANA HOMELAND SECURITY



Underground Storage Tank

CHRIS ZELL
316 W INDIANA AVE
CHESTERTON, INDIANA

STATE/PERMIT #
UC111987

ISSUE
12/29/2022

EFFECTIVE
12/30/2022

EXPIRATION
12/29/2024

DISCIPLINES

☒ Installation or Retrofitting

☐ Decommissioning Closure

☐ Cathodic Protection

☐ Decommissioning Removal

☐ Testing

The attached testing was completed at this site by an IDHS certified technician.

Technician's Signature: _____

Chris Zell


Midwest Tank Testing
AN ENVIRONMENTAL COMPLIANCE COMPANY

316 W. Indiana Ave.
Chesterton, IN 46304
(800) 975-1436

Serving the Midwest Since 1990