

TRIENNIAL INSPECTION

Facility Name: GO LO

Test Date: 06/27/2025

Facility Address: 3479 GEORGIA STREET GARY IN 46409

Facility ID: 7606

OVERFILL PREVENTION EQUIPMENT INSPECTION

Tank ID #	T1	T2				
Product	Reg	PUL				
Tank Volume (gallons)	12,000	8,000				
Tank Diameter (Inches)	91.625	91.125				
Calculated 90% Level (Inches)	76.875	76.625				
Calculated 95% Level (Inches)	81.125	81				

Automatic Shutoff Device (Flapper Valve) Inspection

Measured Shutoff Level (Inches)	81.125	81				
Drop tube removed from tank?	YES	YES				
Drop tube and float mechanism free of debris?	YES	YES				
Float moves freely and poppet moves into flow path?	YES	YES				
Bypass valve in drop tube open and unblocked?	N/A	N/A				
Flapper valve adjusted to shut off flow at 95% capacity?	Yes	YES				
INSPECTION RESULT	PASS	PASS				

Overfill Alarm Inspection

Electronic device and probe operating properly?						
Alarm activates at 90% of tank capacity?						
Alarm is heard and seen from tank fueling area?						
INSPECTION RESULT						

Comments

Technician Name: Ben Porter

Dispatch # 7719

B&K Equipment completes testing and inspections per recommended practices of PEI RP1200-19