

SUPER GAS FOODMART
3479 GEORGIA STREET
GARY, IN 46407
219-884-3480

MAR 5, 2025 3:34 PM

CSLD TEST RESULTS

MAR 5, 2025 3:34 PM

T 1: UNLEADED
PROBE SERIAL NUM 656657

0.2 GAL/HR TEST
PER: MAR 5, 2025 PASS

T 2: PREMIUM
PROBE SERIAL NUM 656658

0.2 GAL/HR TEST
PER: MAR 4, 2025 PASS

***** END *****

SUPER GAS FOODMART
3479 GEORGIA STREET
GARY, IN 46407
219-884-3480

MAR 5, 2025 3:34 PM

LIQUID STATUS

MAR 5, 2025 3:34 PM

NONE

***** END *****

SUPER GAS FOODMART
3479 GEORGIA STREET
GARY, IN 46407
219-884-3480

MAR 5, 2025 3:34 PM

LEAK TEST REPORT

T 1: UNLEADED
PROBE SERIAL NUM 656657

TEST STARTING TIME:
JAN 24, 2007 1:51 PM

HEIGHT = 36.1 INCHES
WATER = 0.0 INCHES
TEMP = 50.2 F

TEST LENGTH = 2.0 HRS
STRT VOLUME = 4332.5 GAL
PERCENT VOLUME = 37.1

LEAK TEST RESULTS
RATE = -45.95 GAL/HR
THRS = -0.13 GAL/HR
0.20 GAL/HR TEST FAIL

***** END *****

SUPER GAS FOODMART
3479 GEORGIA STREET
GARY, IN 46407
219-884-3480

MAR 5, 2025 3:34 PM

LEAK TEST REPORT

T 2: PREMIUM
PROBE SERIAL NUM 656658

TEST STARTING TIME:
JAN 24, 2007 1:51 PM

HEIGHT = 21.1 INCHES
WATER = 0.0 INCHES
TEMP = 51.9 F

TEST LENGTH = 2.0 HRS
STRT VOLUME = 1351.7 GAL
PERCENT VOLUME = 17.0

LEAK TEST RESULTS
0.20 GAL/HR TEST UNVL

0.20 GAL/HR FLAG:
LOW LEVEL TEST ERROR
PERCENT VOLUME TOO LOW

***** END *****